

| Room Name | Birthing Room - LDR | | Room Number BIRM |
|------------------------------------|--|--|------------------|
| Revision | 3 | | |
| Issue Date | 20.03.17 | | |
| BRIEFING | | | |
| Briefed Area | 28.00 m ² | | |
| Hours of Operation | 24 Hours | | |
| Occupancy | 1 patient; 1-2 support persons; up to 4 staff | | |
| Acoustics | Sound attenuation level high, Acoustic privacy is required. | | |
| Remarks | | | |
| Description / Special Requirements | The Birthing Room LDR provides for the entire process of delivery including patient preparation, relaxation and analgesia during labour, delivery, infant resuscitation, post natal recovery and observation. The Birthing Room shall include a scrub basin. Clinical items such as medical gases and services may be concealed but within easy reach. | | |
| SERVICES | | | |
| General Requirements | BODY PROTECTED = Yes | CARDIAC PROTECTED = No | |
| Air | AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No | AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No | |
| Lighting | LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No | LIGHTING: dimmable = No LIGHTING: downlights, dimmable = Yes LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No | |
| Nurse Call | NURSE CALL SYSTEM = Yes | | |

Room Fabrics

| AusHFG code | Description | Comment |
|-------------|--|--------------------|
| CLFS-006 | CEILING: plasterboard, flush set, suspended, paint, washable | |
| CLCN-006 | CORNICE: plasterboard, 90mm to match ceiling finish, paint | |
| DWSC-021 | DOOR: 1400mm c/o, 1 1/2 leaf, solid core, paint | |
| DWPR-006 | DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished | Equal to 'Acrovyn' |
| DWPR-010 | DOOR PROTECTION: to door frame, PVC, prefinished | Equal to 'Acrovyn' |
| FLVY-006 | FLOOR FINISH: vinyl, seamless, coved, non slip, textured | under basin |
| FLVY-007 | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant | |
| FLSK-010 | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished | |
| WLWA-004 | WALL FINISH: paint, acrylic, washable | |
| WLWA-010 | WALL FINISH: splashback, vinyl | to basin |
| WLPR-002 | WALL PROTECTION: bed protection wall panel, composite, laminate finish | |
| WLPR-012 | WALL PROTECTION: corner guards, to 900 AFFL, prefinished PVC | |
| DWWH-005 | WINDOW | |

Fittings, Furniture and Equipment (FF&E) Items

| AusHFG code | Description | Group | Qty | Comment |
|-------------|------------------|-------|-----|---------|
| MMGE-002 | ADAPTER: suction | 3 | 2 | |

Room Name | Birthing Room - LDR

Room Number BIRM

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---|-------|-----|---------------------------------|
| HYBA-009 | BASIN: handwash, Type A, scrub | 1 | 1 | Refer to BWHS-A (similar) |
| FQBS-001 | BASSINET | 3 | 1 | |
| MMBE-006 | BED: patient, birthing, manual | 3 | 1 | |
| FIJO-020 | BENCH: 600D, open under, laminate finish | 1 | 1 | |
| FQCW-006 | BIN: waste, clinical, 240L | 3 | 1 | |
| FQCW-016 | BIN: waste, general, 20L | 3 | 1 | |
| FQCW-044 | BIN: waste, sharps, wall mounted | 3 | 1 | on trolley |
| FIHR-004 | BRACKET: for display screen, ceiling mounted | 1 | 1 | |
| FIHR-016 | BRACKET: for sharps bin | 2 | 1 | mounted to trolley |
| FIHR-019 | BRACKET: for suction bottle | 2 | 1 | |
| FQBS-022 | CHAIR: recliner, clinical | 3 | 1 | |
| FQBS-030 | CHAIR: visitor, patient | 3 | 1 | |
| FQGE-005 | CLOCK: analogue, battery operated | 3 | 1 | |
| FIJO-122 | CUPBOARD: tall, double door, to conceal services | 1 | 1 | |
| FIJO-130 | CUPBOARD: tall, single door, adj shelves and clothes rail | 1 | 1 | |
| FIJO-143 | CUPBOARD: wall mount, double door, adj shelves | 1 | 2 | over bench |
| FQGE-009 | CURTAIN: bed screen | 3 | 2 | to door entry and resus trolley |
| DWWD-011 | CURTAIN: window, drapes | 3 | 1 | |
| FIDI-014 | DISPENSER: disposable glove | 2 | 1 | |
| FIDI-025 | DISPENSER: paper/hand towel | 2 | 1 | to basin |
| FIDI-030 | DISPENSER: soap | 2 | 1 | to basin |
| FIDI-031 | DISPENSER: soap antiseptic | 2 | 1 | to basin |
| ITBU-012 | DISPLAY SCREEN: patient entertainment system | 1 | 1 | |
| MGFP-002 | FLOWMETER: medical air | 3 | 2 | optional |
| MGFP-004 | FLOWMETER: oxygen | 3 | 3 | |
| LIPO-006 | LIGHT: examination, mobile | 3 | 1 | |
| FQSN-051 | LOCKER: 2 drawers, open under, lockable, mobile | 3 | 1 | |
| FQBS-041 | LOUNGE: 2.5 seat | 3 | 1 | |
| MMMA-011 | MIXER: oxygen and nitrous oxide | 3 | 1 | mobile |
| MMGE-063 | MONITOR: patient, foetal, CTG | 3 | 1 | mobile |
| FIJO-194 | SHELF: laminate | 1 | 1 | near basin |
| FQBS-052 | STOOL: mobile, high, adj height | 3 | 1 | |
| MMGE-100 | SUCTION BOTTLE | 3 | 2 | |
| FQTA-013 | TABLE: overbed | 3 | 1 | |
| HYTP-037 | TAPWARE: mixer, elbow levers | 1 | 1 | |
| ITNE-049 | TELEPHONE: handset, desktop | 3 | 1 | |
| FIRT-023 | TRACK: curtain, bedscreen, L shaped | 1 | 1 | to door entry |
| FIRT-028 | TRACK: curtain, ceiling mounted | 1 | 1 | to baby resus area |

Room Name | Birthing Room - LDR

Room Number BIRM

| AusHFG code | Description | Group | Qty | Comment |
|-------------|-----------------------------|-------|-----|---------|
| FIRT-030 | TRACK: curtain, flat pelmet | 1 | 1 | |
| FQSM-016 | TROLLEY | 3 | 1 | |
| MMMA-015 | WARMER: infant, radiant | 3 | 1 | |

Engineering Services

| AusHFG code | Description | Group | Qty | Comment |
|-------------|--|-------|-----|--|
| ITCL-004 | BUTTON: nurse call, emergency | 1 | 1 | + indicator button & light |
| ITCL-006 | BUTTON: nurse call, patient to staff | 1 | 1 | to wall panel, + indicator button & light |
| ITCL-008 | BUTTON: nurse call, staff assist | 1 | 1 | to wall panel, + indicator button & light |
| ELGP-208 | GPO: double, wall mounted | 1 | 3 | bench & walls, optional |
| ELGP-209 | GPO: double, wall mounted, RCD protected | 1 | 1 | to wall panel |
| ELGP-122 | GPO: emergency power, single, on services panel | 1 | 2 | to services panel, 2- baby |
| ELGP-123 | GPO: emergency power, single, wall mounted | 1 | 4 | to wall panel, 4-mother |
| ELGP-101 | GPO: single, ceiling mounted | 1 | 1 | for ceiling mounted display screen (TV) |
| ELGP-105 | GPO: single, on services panel | 1 | 4 | to services panel; 4-baby |
| ELGP-109 | GPO: single, wall mounted | 1 | 4 | to wall panel; 4-mother |
| ELGP-109 | GPO: single, wall mounted | 1 | 1 | low level, for electric bed |
| ELGP-110 | GPO: single, wall mounted, cleaner | 1 | 1 | |
| ITCL-028 | HANDSET: nurse call, with patient to staff call button | 1 | 1 | to wall panel, with light switch |
| LIFX-011 | LIGHT: reading light | 1 | 1 | |
| LIFX-008 | LIGHT: task light, built in | 1 | 1 | to overbench cupboards |
| ITIN-026 | OUTLET: data, double RJ45, wall mounted | 1 | 1 | above bench, 1 outlet for telephone |
| ITIN-026 | OUTLET: data, double RJ45, wall mounted | 1 | 1 | to wall panel |
| ITIN-070 | OUTLET: MATV | 1 | 1 | |
| MGAS-022 | OUTLET: medical air (MA), on services panel | 1 | 2 | 1-mother (in cupboard); 1 baby (services panel) |
| MGAS-032 | OUTLET: nitrous oxide (N2O), on services panel | 1 | 1 | 1-mother (in cupboard) |
| MGAS-042 | OUTLET: oxygen (O2), on services panel | 1 | 3 | 2-mother (in cupboard); 1-baby (services panel) |
| MGAS-053 | OUTLET: scavenge, on services panel | 1 | 1 | 1-mother (in cupboard) for N2O |
| MGAS-062 | OUTLET: suction, on services panel | 1 | 2 | 1-mother (in cupboard); 1 baby (services panel) |
| MMSP-026 | SERVICES PANEL: wall mounted | 2 | 1 | plus two panels in the form of bedhead wall protection and in cupboard |
| ELBO-015 | SWITCH: light, single | 1 | 3 | to wall panel, to ensuite, to store |