



Room Name	Clean Store / Medication Room, 20	m2	Room Number CLN-MED-20	
Revision	1			
Issue Date	18.01.2021			
BRIEFING				
Briefed Area	20.00 m ²			
Hours of Operation	24 Hours			
Occupancy	1 - 2 staff intermittently			
Acoustics				
Remarks				
Description / Special Requirements	secure storage of medications, including i dependence in accordance with relevant I medication storage and internal temperati room is required. The provision and place	ntrave egisla ures s ment	rides a space for the storage of clean consumables and the enous fluids. The room may provide storage for drugs of tion. Controlled temperature and humidity is required for hould not rise above 25°C. Secured staff only access to the of CCTV cameras is dependent on jurisdictional policies. Ren of automated medication management systems.	e efer
SERVICES				
General Requirements	BODY PROTECTED		CARDIAC PROTECTED	
Air	AIRCONDITIONING AIRCONDITIONING: positive pressure EXHAUST: room exhaust	V	AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION	
Lighting	LIGHTING: colour corrected		LIGHTING: dimmable	
	LIGHTING: downlights		LIGHTING: downlights, dimmable	
	LIGHTING: fluorescent/LED, downlights		LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	
	LIGHTING: fluorescent/LED, general	√	LIGHTING: indirect	
Nurse Call	NURSE CALL SYSTEM			

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-003	DOOR: 910mm c/o, single leaf, half glazed, solid core/safety glass, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	extent dependent on type and height storage solution
WLWA-023	WALL FINISH: vinyl, to 2100 AFFL	extent dependent on type and height storage solution

Fittings, Furniture and Equipment (FF&E) Items



Page: 1 Print Date: 14/01/2021





Room Name

Clean Store / Medication Room, 20m2

Room Number CLN-MED-20

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-061	BIN: waste, pharmaceutical	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	
FIJO-212	BULKHEAD: joinery	1	1	plasterboard bulkhead also acceptable
ITSE-012	CAMERA: CCTV	1	1	optional, provision and placement dependent on local policies
FIJO-108	CUPBOARD: drawer unit, baskets, 3 x Wire (400mm wide)	1	8	
FIJO-145	CUPBOARD: wall mount, double door, adj shelves, lockable	1	1	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	2	
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
FIDI-052	DISPENSER: sticker roll	2	1	optional
MMGE-034	FRIDGE: drugs, large	3	1	size and quantity to be based on service requirements
MMGE-087	SAFE: dangerous drugs, medium	1	1	size and quantity to be based on service requirements
FQSM-046	SHELVING: storage solution, 600W x 400D x 2100H nom., wire, mobile	3	5	type and quantity of storage options to be determined based on service requirements
FQSM-048	SHELVING: storage solution, shelving, 600W x 400D x 2100H nom., wire, mobile	3	4	type and quantity of storage options to be determined based on service requirements
HYTP-037	TAPWARE: mixer, elbow levers	1	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-223	GPO: emergency power, double, wall mounted	1	2	optional, for future provision of automated dispensing cabinets
ELGP-123	GPO: emergency power, single, wall mounted	1	1	to drug fridge
LIFX-008	LIGHT: task light, built in	1	2	under wall mounted joinery
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	3	2 x optional, for future provision of automated dispensing cabinets
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	to drug fridge, for temperature monitoring
ITSE-038	READER: access control, general	1	2	

AHHA

aviralision health infrastructure alliance

scriptures: Dissentative St. and and a realize blocker

scriptures: Dissentative St. and and are staller blocker

scriptures: Dissentative St. and and are staller blocker

Page: 2 Print Date: 14/01/2021



RDS Templates



Room Name Clean Store / Medication Room, 20m2 **Room Number CLN-MED-20**

AusHFG code	Description	Group	Qty	Comment
ELBO-010	SWITCH: light, 2-way	1	2	
ELBO-015	SWITCH: light, single	1	1	to task light

AHHA