



Room Name	Clean-Up Room, 7m2	Room Number CLUP-7
Revision	4	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	7.00 m <sup>2</sup>	
Hours of Operation	24 Hours	
Occupancy	1 - 2	
Acoustics		
Remarks		
Description / Special Requirements	The Clean-Up Room is used for holding of use Items may be sorted, rinsed or disposed of and	ed trolleys and articles from an Operating or Procedure room.  d despatched to waste holding/ CSSU areas as appropriate.
SERVICES		
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No	

## **Room Fabrics**

AusHFG code	Description	Comment
CLTI-014	CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	As required; Equal to Acrovyn

## Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	elbow action levers
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	with wet edge
FQCW-006	BIN: waste, clinical, 240L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	over bench

Generated from dRofus © 2017 dRofus Pty Ltd

Page: 1 Print Date: 20/03/2017

AHHA
assistents at the of assistence





**Room Name** 

Clean-Up Room, 7m2

## **Room Number CLUP-7**

AusHFG code	Description	Group	Qty	Comment
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
FIHR-049	RACK: mop	1	1	4 hooks
FIJO-197	SHELF: stainless steel, underbench	1	1	
HYBA-040	SINK: cleaner	1	1	
HYBA-052	SINK: single, 450 x 350 x 250D	1	1	hot water
HYTP-037	TAPWARE: mixer, elbow levers	1	3	1 to sink, 1 to basin, 1 to cleaner's sink
FQSM-016	TROLLEY	3	1	

## **Engineering Services**

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	1	
ELBO-015	SWITCH: light, single	1	1	



Page: 2 Print Date: 20/03/2017