

Room Name | Consult Room - ENT/ Ophthalmology

Room Number: CONS-ENT-OP

Last modified	01/03/2016
Briefed Area	12.00
Remarks	For bariatric consult requirements refer to Treatment Room options
Occupancy	1 patient: 1-2 staff, 1-2 visitors
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	Sound attenuation level high, Acoustic privacy is required.
Description / Special Requirements	The Consult Room ENT/ Ophthalmology will provide for private consultation and examination of patients for ENT/ Ophthalmology using specialised equipment. The Consult room may also be used for general consultations. A second egress door may be required for staff safety and security and/or staff access. A distance of 3m is required between the eye chart and mirror for effective use. Requires dimmable lighting. Acoustics: Sound attenuation level - high; Acoustic privacy essential. Body Protected electrical area

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Default = vinyl: Carpet also acceptable
1020	Floor finish	Vinyl, non-slip	Safety	Seamless, coved	Under basin, significant change in colour to be avoided.
3000	Wall finish	Paint	Acrylic, washable		
2906	Wall finish			Splashback behind basin	Selection of material to comply with Part D Infection Prevention & Control AusHFG.
5007	Ceiling - Plasterboard	Plasterboard	Paint	Bulkhead	Between above bench joinery and ceiling, default joinery
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
9125	Door - 1400mm	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel	910/1400mm clear opening or a 1200mm clear opening single door. Bariatric provision to be decided at project level.
2529	Door protection	Composite	Prefinished PVC	To door frame	
2712	Door protection			Protection plate to 900 AFFL	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Default = coved skirting: or vinyl featheredge skirting over carpet

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-13725	Mirror - hinged		3	1 wall mounted, for eye chart
FF-1465	Bracket - suction bottle		2	1 optional
FF-1470	Bracket - sharps		2	1
FF-150	Air flowmeter		3	1 optional
FF-16250	Oxygen flowmeter		3	1 optional
FF-17360	Pinboard - fabric covered		1	1 Over desk, optional

Room Name | Consult Room - ENT/ Ophthalmology

Room Number: CONS-ENT-OP

AusHFG code	Description	Group	Qty	Comments
FF-19700	Sharps bin	3	1	Wall mounted
FF-20000	Shelving unit - adjustable	1	1	Over desk, number to suit
FF-2100	Chair - ergonomic, office	3	1	
FF-21950	Suction adapter	3	1	optional
FF-22000	Suction bottle	3	1	optional
FF-2600	Chair - visitor, office	3	2	Consider weight capacity of chair
FF-3400	Coathook	1	2	
FF-4600	Curtain track - bed screen	1	1	to exam couch
FF-5000	Curtain - bed screen	3	1	
FF-5900	Desk	3	1	
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to hand basin
FF-6156	Dispenser - soap	2	1	to hand basin
FF-6158	Dispenser - soap antiseptic	2	1	to hand basin
FF-6153	Dispenser - moisturiser	2	1	Depends on operational policy
FF-5830	Dispenser - antiseptic hand rub	2	1	
FF-5824	Waste bin - general	3	2	To hand basin
FF-21020	Sphygmomanometer - portable	3	1	1 per 6 consult rooms, ratio to be determined at project level
FF-775	Dispenser - bed roll	2	1	Or provided as an attachment to exam couch
FF-7100	Trolley - ENT	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11400	Computer - PC & monitor	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	To desk, high resolution for PACS viewing
FE-15900	Diagnostic set - wall mounted	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-20350	Examination couch - electric	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hi/Low operation
FE-2800	Basin - handwash, Type B	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Tapware; elbow action levers or handsfree optional
FE-31701	Light - examination, wall mount	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	wall mounted or ceiling mounted, optional

Room Name | Consult Room - ENT/ Ophthalmology

Room Number: CONS-ENT-OP

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-36915	Light box - eye chart	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Consider use of a wall monitor for viewing eye charts as an alternative and where used include bracket, power and data as needed.
FE-41100	Printer - networked	3	0	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	EMR/E-med compatible. Optional printing strategy (centralised vs. decentralised) to be decided at project level.					
FE-44360	Refrigerator - drugs, small	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	eye medications					
FE-50600	Slit lamp	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-54520	Telephone - handset, handsfree	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	to desk					
FE-5836	Xray viewer - 2 screen, portable	3	0	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	1 per department, number and location to be determined at project level

Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	3	Bedhead low level, for electric bed
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9000	GPO: Single	1	1	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	1	monitor
S-9001	GPO: Double	1	1	
S-9001	GPO: Double	1	2	
S-9011	GPO: Emergency power, double (H)	1	1	for refrigerator
S-9040	Body protected	1	1	

Room Name | Consult Room - ENT/ Ophthalmology

Room Number: CONS-ENT-OP

AusHFG code	Description	Group	Qty	Comments
S-1005	Voice / Data outlet: single	1	1	in ceiling for data projector; optional
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-1085	Temperature monitor & alarm	1	1	to fridge
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-10005	Duress alarm	1	1	
S-7000	Oxygen (O2)	1	1	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	
S-11000	Wall panel	2	1	patient services panels