

Room Name	Consult Room - ENT/ Ophthalmology		Room Number CONS-ENT-OP
Revision	5		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	12.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 patient: 1-2 staff, 1-2 visitors		
Acoustics	Sound attenuation level high, Acoustic privacy is essential.		
Remarks	For bariatric consult requirements refer to Treatment Room options		
Description / Special Requirements	The Consult Room ENT/ Ophthalmology will provide for private consultation and examination of patients for ENT/ Ophthalmology using specialised equipment. The Consult room may also be used for general consultations. A second egress door may be required for staff safety and security and/or staff access. A distance of 3m is required between the eye chart and mirror for effective use.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = Yes LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLGE-001	CEILING: plasterboard, bulkhead, paint	Between above bench joinery and ceiling, default joinery
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-022	DOOR: 1200mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	optionally can also be 1200mm clear opening single door or 1400mm clear opening with 910 large leaf. Bariatric provision to be decided at project level.
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	Under basin, significant change in colour to be avoided
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Carpet also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	Feather edge vinyl skirting if carpeted
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	Selection of material to comply with Part D Infection Prevention & Control AusHFG.

Room Name | Consult Room - ENT/ Ophthalmology

Room Number CONS-ENT-OP

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	optional
HYBA-010	BASIN: handwash, Type B	1	1	Tapware; elbow action levers or handsfree optional
FQCW-016	BIN: waste, general, 20L	3	2	To hand basin
FQCW-044	BIN: waste, sharps, wall mounted	3	1	Wall mounted
MMAH-006	BOX: light, eye chart	3	1	Consider use of a wall monitor for viewing eye charts as an alternative and where used include bracket, power and data as needed.
FIHR-016	BRACKET: for sharps bin	2	1	
FIHR-019	BRACKET: for suction bottle	2	1	optional
FQBS-018	CHAIR: office, ergonomic	3	1	
FQBS-028	CHAIR: visitor, clinical areas	3	2	Consider weight capacity of chair
ITNE-007	COMPUTER: desktop, with display screen	3	1	To desk, high resolution for PACS viewing
MMBE-023	COUCH: examination, electric, mobile	3	1	Hi/Low operation
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	1	Over desk, number to suit
FQGE-009	CURTAIN: bed screen	3	1	
FQDW-001	DESK: adj height, 1100W x 600D x 750H nom.	3	1	
MMAH-013	DEVICE: Eye examination, slit lamp	3	1	
MMGE-031	DIAGNOSTIC SET: wall mounted	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-003	DISPENSER: bedroll	2	1	Or provided as an attachment to exam couch
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-022	DISPENSER: moisturiser	2	1	to hand basin. Depends on operational policy.
FIDI-025	DISPENSER: paper/hand towel	2	1	to hand basin
FIDI-030	DISPENSER: soap	2	1	to hand basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to hand basin
MGFP-002	FLOWMETER: medical air	3	1	optional
MGFP-004	FLOWMETER: oxygen	3	1	optional
MMGE-035	FRIDGE: drugs, small	3	1	eye medications
FIHR-026	HOOK: coat	1	2	
LIFX-026	LIGHT: examination, wall mounted	1	1	wall mounted or ceiling mounted, optional
FIBM-011	MIRROR: hinged, glass	3	1	wall mounted, for eye chart
FIBM-013	NOTICEBOARD: fixed, fabric covered	1	1	Over desk, optional
ITNE-023	PRINTER: networked	3	0	EMR/E-med compatible. Optional printing strategy (centralised vs. decentralised) to be decided at project level.

Room Name | Consult Room - ENT/ Ophthalmology
Room Number CONS-ENT-OP

AusHFG code	Description	Group	Qty	Comment
MMGE-091	SPHYGMOMANOMETER: portable	3	1	1 per 6 consult rooms, ratio to be determined at project level
MMGE-100	SUCTION BOTTLE	3	1	optional
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-050	TELEPHONE: handset, desktop, handsfree	3	1	to desk
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	1	To exam couch
MMGE-117	TROLLEY: ENT	3	1	
MMGE-153	VIEWER: X-ray, 2 screen, mobile	3	0	1 per department, number and location to be determined at project level

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITBU-001	ALARM: equipment monitoring, temperature	1	1	Refrigerator if required
ITSE-006	BUTTON: duress, fixed	1	1	
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
ELGP-205	GPO: double, on services panel	1	1	patient examination area
ELGP-208	GPO: double, wall mounted	1	2	workstation / desk area
ELGP-222	GPO: emergency power, double, on services panel	1	1	patient examination area
ELGP-123	GPO: emergency power, single, wall mounted	1	1	for fridge, if fridge required
ELGP-105	GPO: single, on services panel	1	1	diagnostic set
ELGP-109	GPO: single, wall mounted	1	4	light box, slit lamp, desk, exam light
ELGP-109	GPO: single, wall mounted	1	1	low level for electric exam couch, optional
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	as required
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	For refrigerator, if refrigerator required
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	optional
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	optional
MGAS-062	OUTLET: suction, on services panel	1	1	optional
MMSP-026	SERVICES PANEL: wall mounted	2	1	
ELBO-015	SWITCH: light, single	1	1	