

Room Name	Dining - Patient		Room Number DINR
Revision	4		
Issue Date	12.07.2023		
BRIEFING			
Briefed Area	40.00 m ²		
Hours of Operation	Up to 24 Hours		
Occupancy	16 patients seated, 3-4 staff intermittently		
Acoustics	Sound attenuation level high; acoustic privacy is required.		
Remarks			
Description / Special Requirements	<p>The Dining Room is an area provided for patients to eat their meals away from the bedroom environment in an inpatient setting. The Dining Room may be used for other patient recreational activities when not in use for meals. In this instance, additional transfer of noise to adjacent patient care areas to be considered.</p> <p><u>Additional Considerations:</u></p> <ul style="list-style-type: none"> Food services model, e.g. meal trolley (tray or re-thermalisation), servery, beverage bay, etc. will impact room design. A kitchen, servery or beverage bay may be collocated or combined with the Dining Room. Size of space will depend on number of beds and models of care; designed area based on 3m² per person. Access will be required for patients with limited mobility including wheelchairs, walking frames and other walking aids. Design must also consider the needs of patients with dementia and frail/elderly. An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements. Patient to nurse call button and handset is optional and may be provided in units where high patient observation is required. Duress provision will be dependent on service requirements. Furniture shown in this Standard Component is indicative and items selected will vary depending on patient cohort. Considerations regarding furniture include assessing the weight rating of all seating, including for bariatric capacity as required, providing a mix of chairs with and without arms to support patient mobility, and providing built-in furniture or securing furniture where there may be safety/security concerns. Lighting to be consistent across the space. Size, type and quantity of waste bins is dependent on environmental management policies and service requirements. Where a facility has additional waste streams, beyond the general waste and comingled recycling indicatively shown in this Standard Component, additional area may be required to accommodate the receptacles. Depending on frequency of waste removal, bin sizes may be larger in high use areas or as guided by local waste management policies. Joinery to conceal bins may be provided depending on infection prevention and control policies. Where possible a achieving a domestic appearance with furniture, fittings and finishes is recommended. The display of artwork and cultural assets will be guided by the facility. A rail display system may be considered to minimise risks and allow for flexibility in display. Ease of cleaning for infection prevention and control also needs to be considered when selecting artwork. Natural light and external outlook is essential. 		
SERVICES			
Electrical	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
HVAC	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input checked="" type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>

Room Name Dining - Patient

Room Number DINR

Security / Nurse Call

LIGHTING: fluorescent/LED, downlights



LIGHTING: fluorescent/LED, flush with ceiling, tamper proof



LIGHTING: fluorescent/LED, general



LIGHTING: indirect



NURSE CALL SYSTEM



Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
DWGL-031	DOOR: 1400mm c/o, 1 1/2 leaf, half glazed, solid core/glass, paint	with hold open device to support trolley movement as required
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10/pendulum P3 or agreed equivalent to extend under basin; significant change in colour to be avoided
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	to basin
WLWA-025	WALL FINISH: vinyl, to 1200 AFFL	to meal trolley parking area
DWWH-005	WINDOW	natural light and external outlook is essential

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQGE-002	ARTWORK	3	1	
HYBA-010	BASIN: handwash, Type B	1	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-019	BIN: waste, general, 50L	3	1	size, type and quantity of bins dependent on local waste management policies
FQCW-062	BIN: waste, recycling, comingled, 50L	3	1	size, type and quantity of bins dependent on local waste management policies
DWWD-004	BLIND: roller	3	2	
FIHR-006	BRACKET: for display screen, wall mounted	2	1	optional
FQBS-015	CHAIR: dining	3	16	furniture is indicative and selection will be dependent on patient/visitor cohort and service requirements
FIJO-104	CUPBOARD: drawer unit, 3 equal	1	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	2	
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin

Room Name | Dining - Patient

Room Number DINR

AusHFG code	Description	Group	Qty	Comment
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
ITBU-011	DISPLAY SCREEN: MATV	3	1	optional
FQTA-059	TABLE: square, 1100W, dining height	3	4	furniture is indicative and selection will be dependent on patient/visitor cohort and service requirements
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	
FQCA-082	TROLLEY: food delivery, hot/cold	3	1	as required to suit food service model

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELPR-001	BODY PROTECTED ELECTRICAL AREA	1	1	
ITCL-004	BUTTON: nurse call, emergency	1	1	with indicator button and light
ITCL-006	BUTTON: nurse call, patient to staff	1	2	optional, dependent on patient cohort, provide in areas requiring high staff observation; with indicator button and light
ITCL-008	BUTTON: nurse call, staff assist	1	2	with indicator button and light
ELGP-208	GPO: double, wall mounted	1	3	
ELGP-208	GPO: double, wall mounted	1	1	optional, to television
ELGP-109	GPO: single, wall mounted	1	1	to meal trolley parking area; power requirements dependent on type of meal trolley
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	optional, dependent on patient cohort, provide in areas requiring high staff observation; with indicator button and light
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	optional, to television, MATV outlet may also be provided depending on local ICT policies
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	to wall mounted telephone
ELBO-015	SWITCH: light, single	1	1	