

Room Name	Disposal Room, 10m2		Room Number DISP-10
<b>Revision</b>	6		
<b>Issue Date</b>	12.07.2023		
<b>BRIEFING</b>			
<b>Briefed Area</b>	10.00 m <sup>2</sup>		
<b>Hours of Operation</b>	Up to 24 Hours		
<b>Occupancy</b>	1-2 staff, accessed intermittently		
<b>Acoustics</b>			
<b>Remarks</b>			
<b>Description / Special Requirements</b>	<p>The Disposal Room provides for the temporary holding of waste, separated into various waste streams (general waste, clinical waste, cardboard recycling, co-mingled recycling, cytotoxic waste, confidential waste, sharps, soiled linen, etc.) prior to removal to a designated waste zone in the loading dock. Waste will be collected at regular times each day, or when requested, to prevent build-up of waste in the unit.</p> <p><u>Additional Considerations:</u></p> <ul style="list-style-type: none"> <li>Size requirements for a Disposal Room will be dependent on a department's estimated waste output, the frequency of waste collection and local operational policies for waste management that may dictate the number of waste streams and minimum bin sizes.</li> <li>Adequate space must be provided to allow for segregation of waste streams.</li> <li>The use of 660 L bins should be carefully considered due to the WHS risks associated with manual handling, however it is acknowledged in some areas with significant waste output they may be required. Where the weight of full waste receptacles is a concern, the use of tugs/AGVs is often required.</li> <li>Waste transfer may be manual, by motorised movers/tugs or via automated guided vehicle (AGV) systems. Where tugs and AGVs are being considered, it is important to confirm clearances, door widths and turning circles within the room, in the adjacent corridor and along path of travel to designated waste zone.</li> <li>Hold open door hardware may be required to allow for easy movement of bins and trolleys in and out of the room.</li> <li>Shelf may be provided for storage of small sharps bins prior to collection.</li> <li>If a handwashing basin is not provided within the Disposal Room, one should be located in close proximity. The location of hand hygiene facilities may be dependent on local infection control policies.</li> <li>Staff only access may be required if this room is provided in a public or patient care area.</li> </ul>		
<b>SERVICES</b>			
<b>Electrical</b>	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>HVAC</b>	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input checked="" type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
<b>Security / Nurse Call</b>	NURSE CALL SYSTEM	<input type="checkbox"/>	

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-008	CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200	

**Room Name** | Disposal Room, 10m2

**Room Number** DISP-10

AusHFG code	Description	Comment
CLCN-009	CORNICE: wall trim fixing	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	lockable or secure staff access, hold open hardware may be required
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-023	WALL FINISH: vinyl, to 2100 AFFL	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	may be provided outside of room depending on local infection control policies
FQCW-006	BIN: waste, clinical, 240L	3	1	size, type and quantity of bins dependent on service requirements and local waste management policies
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-022	BIN: waste, general, skip 660 litre	3	1	size, type and quantity of bins dependent on service requirements and local waste management policies
FQCW-029	BIN: waste, recycling, paper, 240L	3	1	size, type and quantity of bins dependent on service requirements and local waste management policies
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	to basin, locate with alcohol based hand rub if basin is located outside of room
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
FIJO-194	SHELF: laminate	1	1	optional, for storage of small sharps bins
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
MMGE-143	TROLLEY: soiled linen collection	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELBO-015	SWITCH: light, single	1	1	