

Room Name	Disposal Room, 8m2		Room Number DISP-8
<b>Revision</b>	5		
<b>Issue Date</b>	20.03.17		
<b>BRIEFING</b>			
<b>Briefed Area</b>	8.00 m <sup>2</sup>		
<b>Hours of Operation</b>	24 Hours		
<b>Occupancy</b>			
<b>Acoustics</b>			
<b>Remarks</b>			
<b>Description / Special Requirements</b>	The Disposal Room provides for the temporary holding of clinical waste, general waste, sharps, soiled linen and recyclables prior to removal. The Disposal Room should be located in close proximity to a handwashing basin or be provided within the room (optional) if waste will be handled in this area. The room should be lockable.		
<b>SERVICES</b>			
<b>General Requirements</b>	BODY PROTECTED = No		CARDIAC PROTECTED = No
<b>Air</b>	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes		AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
<b>Lighting</b>	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes		LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
<b>Nurse Call</b>	NURSE CALL SYSTEM = No		

RETIRED

**Room Fabrics**

AusHFG code	Description	Comment
CLTI-008	CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	lockable, optional glazed viewing panel to door
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	Default = no hand basin; to basin, if provided
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	as required

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
HYBA-011	BASIN: handwash, Type C	1	1	Default = no hand basin: optional with shroud

**Room Name** | Disposal Room, 8m2

**Room Number** DISP-8

AusHFG code	Description	Group	Qty	Comment
FQCW-006	BIN: waste, clinical, 240L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-017	BIN: waste, general, 240L	3	2	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to hand basin, if provided
FIDI-030	DISPENSER: soap	2	1	to hand basin, if provided
HYTP-036	TAPWARE: mixer, basin, lever action	1	1	
MMGE-143	TROLLEY: soiled linen collection	3	1	

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELBO-015	SWITCH: light, single	1	2	

# RETIRED