

Room Name	Daylight Processing		Room Number DPRO
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	16.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 - 2		
Acoustics			
Remarks			
Description / Special Requirements	Area for automatic daylight processing equipment with sorting and viewing of images and films. The processing area should be located with ready access to X-Ray procedure rooms and reporting rooms.		
SERVICES			
General Requirements	BODY PROTECTED = No		CARDIAC PROTECTED = No
Air	AIRCONDITIONING = No AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No		AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No		LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to sink, tiles also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-031	BENCH: 750D, open under, laminate finish	1	1	Sorting and viewing
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	with inset lab sink
FQCW-016	BIN: waste, general, 20L	3	1	
MLLA-026	CABINET: hazardous goods, small	3	1	chemical storage
FQBS-019	CHAIR: office, ergonomic, high	3	1	to sorting bench
FQGE-005	CLOCK: analogue, battery operated	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	2	under sink bench

Room Name | **Daylight Processing**
Room Number DPRO

AusHFG code	Description	Group	Qty	Comment
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	2	over sink bench
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	5	over sorting bench
MMMI-331	DEVICE: imaging, silver recovery unit	3	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to sink
FIDI-030	DISPENSER: soap	2	1	to sink
WLPT-003	PARTITION: laminate	1	2	under bench
MMMI-344	PROCESSOR: imaging, daylight	3	1	
HYBA-060	SINK: single, 600 x 450 x 450D	1	1	hot water
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	on bench
MMGE-157	VIEWER: X-ray, 6 screen	1	1	over bench

Engineering Services

AusHFG code	Description	Group	Qty	Comment
HYDR-006	DRAIN: tundish	1	1	for processor
ELGP-208	GPO: double, wall mounted	1	4	
ELGP-106	GPO: single, special, for equipment	1	1	for processor
LIFX-008	LIGHT: task light, built in	1	5	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	3	1 outlet on sorting bench for telephone
ELBO-015	SWITCH: light, single	1	2	