



Room Name	Dirty Utility - Sub, 8m2	Room Number DTUR-S				
Revision	5					
Issue Date	20.03.17					
BRIEFING						
Briefed Area	8.00 m ²					
Hours of Operation	24 Hours					
Occupancy	1 - 2 intermittently					
Acoustics	Sound attenuation level high, Acoustic privacy	is required				
Remarks	Godina attenuation lover riight, Accounted privacy	io roquirou.				
Description / Special Requirements	The Dirty Utility - Sub is a small Dirty Utility Room providing for cleaning and holding of used equipment for collection, disposal of clinical and other wastes and soiled linen testing and disposal of patient specimens. Decontamination and storage of patient bedpans, urinals and bowls is optional in the Dirty Utility-Sub. The Dirty Utility -Sub may be located in Allied Health, Imaging or Ambulatory Day Care areas. The room shall not be provided in Inpatient Units used for overnight stay.					
SERVICES						
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No				
Air	AIRCONDITIONING = No	AIRCONDITIONING: hepa filtered = No				
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No				
	EXHAUST: room exhaust = Yes	VENTILATION = Yes				
Lighting	LIGHTING: colour corrected = No	LIGHTING: dimmable = No				
gg	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No				
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No				
	LIGHTING: fluorescent, general = Yes	LIGHTING: indirect = No				
Nurse Call	NURSE CALL SYSTEM = No					

Room Fabrics

AusHFG code	Description	Comment
CLTI-014	CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	pull handle/push plate, closer
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to Acrovyn
FLVY-004	FLOOR FINISH: vinyl, seamless, coved, non-slip, safety	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	Refer to BHWS-B (similar)
FIJO-021	BENCH: 600D, open under, stainless steel lipped	1	1	wet edge
FQCW-004	BIN: waste, clinical, 120L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin

AHHA
autralisian holbi idrastrucher alliano
untrotest in unionen is of our and an activa holoide

Page: 1 Print Date: 21/03/2017





Room Name

Dirty Utility - Sub, 8m2

Room Number DTUR-S

AusHFG code	Description	Group	Qty	Comment
FQCW-044	BIN: waste, sharps, wall mounted	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	
FIJO-146	CUPBOARD: wall mount, double door, adj shelves, waterproof carcassing	1	2	for urinalysis equipment
FIJO-158	CUPBOARD: wall mount, single door, adj shelves, waterproof carcassing	1	1	for urinalysis equipment
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to hand basin
FIDI-030	DISPENSER: soap	2	1	to hand basin
FIHR-025	HOOK: catheter bag	1	2	above rim flushing sink
FIHR-029	HOOK: equipment	1	2	
HYTP-006	HOSE: spray, pressure control	1	1	to flushing rim sink, with flush button
MMGE-048	LINEN CARRIER: dirty, single	3	1	
FIHR-038	RACK: bowl/basin	1	1	optional
FIHR-053	RACK: pan & urinal	1	1	6 pans/ 6 urinals, optional
FIJO-196	SHELF: stainless steel, overbench, wall mount	1	1	over bench, optional in lieu of wall mounted cupboards
FIJO-197	SHELF: stainless steel, underbench	1	1	
HYBA-046	SINK: flushing rim	1	1	& pressure control hose spray, or slop hopper optional
HYBA-052	SINK: single, 450 x 350 x 250D	1	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to sink
MMIC-095	WASHER SANITISER: pan flusher	1	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	1	
ELGP-208	GPO: double, wall mounted	1	1	
ELGP-106	GPO: single, special, for equipment	1	1	Pan/ Utensil Washer-sanitiser
HYTP-008	OUTLET: cold water	1	1	
HYTP-013	OUTLET: hot water	1	1	
ELBO-015	SWITCH: light, single	1	1	

AHHA

Page: 2 Print Date: 21/03/2017