



Room Name	Echocardiography - Trans-oesophagea	Room Number ECHO			
Revision	3				
Issue Date	20.03.17				
BRIEFING					
Briefed Area	30.00 m ²				
Hours of Operation	Available 24 Hours				
Occupancy	1 patient; 1 - 2 staff				
Acoustics	Acoustic privacy is required				
Remarks					
Description / Special Requirements	Room for diagnostic echocardiography procedures including trans-oesophageal echocardiography. Echocardiography procedures may be performed under local anaesthesia. The Echocardiography room should be located close to patient toilet and change rooms.				
CEDVICES					
SERVICES General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No			
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No			
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = Yes LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No			
Nurse Call	NURSE CALL SYSTEM = Yes				

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-021	DOOR: 1400mm c/o, 1 1/2 leaf, solid core, paint	
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin; tiles also acceptable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	patient services panel
HYBA-010	BASIN: handwash, Type B	1	1	
MMBE-014	BED: patient, ICU, electric with mattress	3	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin

AHHA
assistation health infrastructure allocore
commence consumers of the consumers of the

Page: 1 Print Date: 20/03/2017





Room Name

Echocardiography - Trans-oesophageal

Room Number ECHO

AusHFG code	Description	Group	Qty	Comment
FQBS-014	CHAIR: client	3	1	
FQBS-018	CHAIR: office, ergonomic	3	1	
FQGE-005	CLOCK: analogue, battery operated	3	1	
MMBE-024	COUCH: examination, manual, mobile	3	1	
FIJO-116	CUPBOARD: tall, double door, adj shelves	1	1	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	adjustable shelves
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	2	over bench
FQGE-010	CURTAIN: privacy screen	3	1	to entry door
MMMI-325	DEVICE: imaging, echocardiography machine	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	patient services panel
MGFP-004	FLOWMETER: oxygen	3	1	patient services panel
FQBS-037	FOOTSTOOL	3	1	
FIHR-026	HOOK: coat	1	1	
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	optional
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	to entry door
MMGE-152	VIEWER: X-ray, 2 screen	1	1	optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	
ITCL-006	BUTTON: nurse call, patient to staff	1	2	1- bed area; 1 - exam couch; bed and couch may share one point if handset will reach both
ITCL-008	BUTTON: nurse call, staff assist	1	2	on services panel and wall mounted
ELGP-208	GPO: double, wall mounted	1	4	
ELGP-122	GPO: emergency power, single, on services panel	1	4	on services panel
ELGP-101	GPO: single, ceiling mounted	1	1	exam light
ELGP-106	GPO: single, special, for equipment	1	2	Echocardigraphy machine, XRV
ELGP-109	GPO: single, wall mounted	1	2	to exam couch
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	2	1- bed area; 1 - exam couch; bed and couch may share one point if handset will reach both
LIFX-008	LIGHT: task light, built in	1	2	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	



Room Data Sheet



Room Name Echocardiography - Trans-oesophageal **Room Number ECHO**

AusHFG code	Description	Group	Qty	Comment
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	1	
MMSP-026	SERVICES PANEL: wall mounted	2	1	
ELBO-015	SWITCH: light, single	1	3	

