Australasian Health Facility Guidelines

Room Data Sheet





Exit Bay

Room Code	EXIT
Briefed Area	11.00 m²
Ceiling Height	2.7 m
Occupancy	staff intermittently
Hours of Operation	Up to 24 hours

Description

The Exit Bay provides area for patients and equipment to be moved from the Operating Room at the conclusion of a procedure. The Exit Bay provides space for the temporary storage of a patient bed while a procedure is in progress. Direct access to the Operating Room is required.

Electrical Lighting	PROTECTION: body protected PROTECTION: cardiac protected LIGHTING: general LIGHTING: colour corrected LIGHTING: dimmable LIGHTING: indirect	4	HVAC	AIRCONDITIONING: general AIRCONDITIONING: HEPA filtered AIRCONDITIONING: positive pressure AIRCONDITIONING: negative pressure VENTILATION: exhaust VENTILATION: supply	4
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset NURSE CALL SYSTEM: annunciator DURESS: fixed DURESS: wireless coverage		Medical Gas	VENTILATION: natural MEDICAL GAS: general anaesthesia MEDICAL GAS: special care MEDICAL GAS: special care, neonatal ventilation MEDICAL GAS: birthing	
Security	ACCESS CONTROL: to door ACCESS CONTROL: to item / joinery INTERCOM: service communications INTERCOM: security and access control CCTV: camera coverage within room INTRUSION DETECTION: door monitoring		Hydraulic Fire	WATER: drinking WATER: specialty DRAINAGE: sanitary DRAINAGE: specialty DETECTION: smoke	
ICT and Audio Visual	INTRUSION DETECTION: spatial monitoring AUDIO VISUAL: patient entertainment system AUDIO VISUAL: visitor experiance system AUDIO VISUAL: virtual collaboration system		Shielding	SHIELDING: ionising radiation SHIELDING: magentic and radio frequency	□ ✓
Accessibility	AUDIO VISUAL: clinical support system AUDIO VISUAL: digital operating room system AUDIO: hearing augmentation VISUAL: luminance contrast SIGNAGE: accessible, statuatory		Acoustics	SPEECH PRIVACY: not private	sitive

Additional Considerations

- Automated doors with motion or elbow activation are provided to the Operating Room from the Exit Bay. Buttons/sensors should be appropriately located in relation to the door, including consideration for approach and movement of patients on beds and mobile equipment. 2-gang buttons that support the opening of either one or both leaves of the door as required are desirable.
- A cupboard for digital operating room (DOR) ICT/AV equipment is indicated on the layout but is not included in the overall area measurement and the contents of the ICT/AV cupboard are not captured in this Standard Component. The size of the ICT/AV cupboard will vary depending on equipment to be accommodated. Rather than being located individually to each Operating Room, ICT/AV equipment may be consolidated in a room that is shared between a number of Operating Rooms as appropriate to suit equipment installation, testing and maintenance requirements.
- Medical gas valve boxes for each Operating Room are typically located in the associated Exit Bay. Size and location of the medical gas valve box zone, to be kept clear of all other services, is to be confirmed by a medical gas engineering consultant.

ALHA SAUSTIG Revision: 1

Page: 1 of 2 Room code: EXIT

- Height and type of wall finish to suit local infection prevention and control policies and rigorous cleaning regimes. Provision and height of corner guards as required to provide protection from anticipated mobile equipment movement.
- Depending on the use of x-ray equipment within the adjacent Operating Room, radiation shielding may be required to this room and is to be assessed by a Radiation Consultant.



Doors and Windows

(CODE	DESCRIPTION	COMMENT	
	DOHI-212.03	DOOR: hinged, 2 leaves, 1600 clear opening, solid, standard vision panel, with cover	to operating room (see OR-GEN)	
	AFDPR-006.05	DOOR PROTECTION: plate, full height	to both sides of door	
	AHDEC-036	SWITCH: door release, double gang, automatic door, wall mounted	to allow for opening either one or both leaves of the door	
	DOHI-001.01	DOOR: hinged, 1 leaf, 800 clear opening, solid	to ICT/AV cupboard	
	AFDPR-006.01	DOOR PROTECTION: plate, to 900H		



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	
WLFI-011.07	WALL FINISH: vinyl, full height	
WLPR-006.07	WALL PROTECTION: corner guards, full height	
CLFS-011	CEILING: flush set, suspended	
CLCN-031	CORNICE: square set	



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	2	1	
FIHR-030	HOOK: equipment, patient slide	0	1	
FIHR-171	BRACKET: gas cylinder, single, wall mounted	0	1	clear space above the bracket for loading/ unloading of the cylinder
MGGE-011.01	CYLINDER: medical gas, C size, oxygen	3	1	
MMBE-031	SLIDE: patient transfer	3	1	



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-231	GPO: double, emergency power, wall mounted	0	1	
MGFP-011	VALVE BOX: medical gases	0	1	

Copyright © 2025 Australasian Health Infrastructure Alliance (AHIA)

Issue date: 06.05.2025
Revision: 1

Page: 2 of 2 Room code: EXIT