

Room Name	Lounge - Patient / Visitor, 10m2		Room Number	LNGE-10
Revision	6			
Issue Date	12.07.2023			
BRIEFING				
Briefed Area	10.00 m ²			
Hours of Operation	Up to 24 Hours			
Occupancy	Up to 6 patients/visitors; 1-2 staff intermittently			
Acoustics	Sound attenuation level medium; acoustic privacy is required.			
Remarks				
Description / Special Requirements	The Patient Lounge provides an environment away from clinical areas and/or patient bedrooms for patients and visitors to meet and socialise. It is an area where family groups can visit together with patients. A range of occupants will need to be accommodated including adults, children, able-bodied people as well as people with disabilities. <u>Additional Considerations:</u> • The size of lounge areas can vary depending on service requirements; add 1.2m2 per additional person and allow 1.5m2 for additional wheelchair spaces as required. • Access for a patient lifter or patient bed may be required depending on patient cohort and service requirements. • The Patient Lounge is often located in close proximity to or combined with a Bay - Beverage. • An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements. Patient to nurse call button and handset is optional and may be provided in units where high patient observation is required. • Duress provision will be dependent on service requirements. • Provision of a hearing augmentation system may be required depending on television and amplification system provided. • Furniture shown in this Standard Component is indicative and items selected will vary depending on patient cohort. Considerations regarding furniture include assessing the weight rating of all seating, including for bariatric capacity as required, providing a mix of chairs with and without arms to support patient mobility, and providing built-in furniture or securing furniture where there may be safety/security concerns. • Room may be designed to be open to a corridor. Additional transfer of noise to adjacent patient care areas to be considered if room is not enclosed. • The display of artwork and cultural assets will be guided by the facility. A rail display system may be considered to minimise risks and allow for flexibility in display. Ease of cleaning for infection prevention and control also needs to be considered when selecting artwork. • Natural light and external outlook is essential.			
SERVICES				
Electrical	BODY PROTECTED	☒	CARDIAC PROTECTED	☐
HVAC	AIRCONDITIONING	☒	AIRCONDITIONING: hepa filtered	☐
	AIRCONDITIONING: positive pressure	☐	AIRCONDITIONING: negative pressure	☐
	EXHAUST: room exhaust	☐	VENTILATION	☐
Lighting	LIGHTING: colour corrected	☐	LIGHTING: dimmable	☐
	LIGHTING: downlights	☐	LIGHTING: downlights, dimmable	☐
	LIGHTING: fluorescent/LED, downlights	☐	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	☐
	LIGHTING: fluorescent/LED, general	☒	LIGHTING: indirect	☒
Security / Nurse Call	NURSE CALL SYSTEM	☒		

Room Fabrics

Room Name | Lounge - Patient / Visitor, 10m2

Room Number LNPT-10

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
DWGL-002	DOOR: 910mm c/o, single leaf, half glazed, solid core/glass, paint	
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	carpet tiles are also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	to be feather edge vinyl for carpet tiles
WLWA-004	WALL FINISH: paint, acrylic, washable	
DWWH-005	WINDOW	natural light and external outlook is essential

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQGE-002	ARTWORK	3	2	
DWWD-004	BLIND: roller	3	1	
FIHR-006	BRACKET: for display screen, wall mounted	2	1	
MMGE-019	CHAIR: patient	3	2	furniture is indicative and selection will be dependent on patient/visitor cohort and service requirements
ITBU-011	DISPLAY SCREEN: MATV	3	1	
FQBS-043	LOUNGE: 2 seat, 1600 wide	3	1	furniture is indicative and selection will be dependent on patient/visitor cohort and service requirements
FQTA-075	TABLE: square, 600W, low height	3	2	furniture is indicative and selection will be dependent on patient/visitor cohort and service requirements

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELPR-001	BODY PROTECTED ELECTRICAL AREA	1	1	
ITCL-004	BUTTON: nurse call, emergency	1	1	with indicator button and light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	optional, dependent on patient cohort, provide in areas requiring high staff observation; with indicator button and light
ITCL-008	BUTTON: nurse call, staff assist	1	1	with indicator button and light
ELGP-208	GPO: double, wall mounted	1	3	1 to television, 2 to room
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	optional, dependent on patient cohort, provide in areas requiring high staff observation; with indicator button and light
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	to television, MATV outlet may also be provided depending on local ICT policies
ELBO-015	SWITCH: light, single	1	1	