Australasian Health Facility Guidelines

Room Data Sheet





Mammography Room

| Room Code | MAMMO |
|--------------------|----------------------|
| Briefed Area | 18.00 m² |
| Ceiling Height | 2.7 m |
| Occupancy | 1 patient; 1-2 staff |
| Hours of Operation | Up to 24 hours |

Description

The Mammography Room provides the space and equipment for undertaking diagnostic and screening mammography, as well as performing minor procedures such as biopsies.

| | performing million procedures such as biopsies. | | | | |
|--------------------------|--|---------------|-------------|---|-----------------------|
| Electrical Lighting | PROTECTION: body protected PROTECTION: cardiac protected LIGHTING: general LIGHTING: colour corrected LIGHTING: dimmable LIGHTING: indirect | | HVAC | AIRCONDITIONING: general AIRCONDITIONING: HEPA filtered AIRCONDITIONING: positive pressure AIRCONDITIONING: negative pressure VENTILATION: exhaust VENTILATION: supply VENTILATION: natural | 4 |
| Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset NURSE CALL SYSTEM: annunciator DURESS: fixed DURESS: wireless coverage | 4 | Medical Gas | MEDICAL GAS: general anaesthesia MEDICAL GAS: special care MEDICAL GAS: special care, neonatal ventilation MEDICAL GAS: birthing | |
| Security | ACCESS CONTROL: to door ACCESS CONTROL: to item / joinery INTERCOM: service communications INTERCOM: security and access control CCTV: camera coverage within room | 3 | Hydraulic | WATER: specialty | ✓ □ ✓ □ |
| | INTRUSION DETECTION: door monitoring INTRUSION DETECTION: spatial monitoring | | Fire | DETECTION: smoke DETECTION: heat | |
| ICT and Audio Visual | AUDIO VISUAL: patient entertainment system AUDIO VISUAL: visitor experiance system | | Shielding | SHIELDING: ionising radiation SHIELDING: magentic and radio frequency | ⊿ |
| | AUDIO VISUAL: virtual collaboration system AUDIO VISUAL: clinical support system AUDIO VISUAL: digital operating room system | | Acoustics | SPEECH PRIVACY: not private ······· moderate ······ private ····· confider NOISE SENSITIVITY: | ntial |
| Accessibility | AUDIO: hearing augmentation VISUAL: luminance contrast SIGNAGE: accessible, statuatory | □ ✓ | | not sensitive medium sensitive sensitive sensitive low moderate high very h | |

Additional Considerations

- Equipment is to be installed to manufacturer's specifications with sufficient clearances for maintenance access. Installation and replacement access routes should also be considered. Additional building services connections and outlets are to be coordinated to suit equipment requirements. Cable ducts for services between the imaging device and the control area will be required and must be coordinated with the MME vendor.
- Radiation shielding requirements are to be assessed and advised by a qualified Radiation Consultant to suit the practice, workload and equipment procured, and all shielding on the Standard Component is indicative. Depending on the equipment selected, a door may be required between the imaging area and the control area to provide adequate shielding.
- An 'X-ray in Use' light system is required with signs that are illuminated when the imaging device is on and turned off when it stops. Signs are to be at all doors entering the room.
- The room will require sufficient clearance to allow access for a patient on a bed.

Issue date: 15.05.2025 Page: 1 of 4
Revision: 5 Copyright © 2025 Australasian Health Infrastructure Alliance (AHIA) Room code: MAMMO

- Close access to a patient toilet and change room is required, with direct access from the room being preferred to support patients that have changed into gowns.
- Provision of height adjustable workstations or fixed joinery is to be in line with service requirements and local WHS policies.
- The type, extent and configuration of storage within the room for consumables, linen, equipment, etc. will be dependent on service requirements, operational policies for stock centralisation/decanting and infection prevention and control policies.
- Hours of operation depend on the service in which this room is located. Ambulatory medical imaging services may only operate during business hours or extended business hours, some small hospital services may have an on-call, after-hours service. Large units are likely to provide a 24-hour service, especially where a satellite service is provided with an emergency department.
- Requirement for fixed and/or mobile duress to be confirmed to suit service requirements.
- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements.
- Provision of an intercom for staff communication within the department is dependent on service requirements. This function may be provided as part of the telephone system.
- The final services and configuration of the Medical Services Panel (MSP) medical gases, nurse call, power and data will be dependent on service requirements.
- The need for and extent of emergency power and UPS must be reviewed to suit site specific requirements and confirmed based on risk assessment considering the impact of a power outage on patient care/safety.



Doors and Windows

| (| CODE | DESCRIPTION | COMMENT |
|---|--------------|---|-----------------------|
| | DOHI-104.02 | DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, shielded | |
| | AFDPR-006.01 | DOOR PROTECTION: plate, to 900H | to both sides of door |



Finishes

| CODE | DESCRIPTION | COMMENT |
|-------------|---|--|
| FLVY-101 | FLOOR FINISH: vinyl, seamless, standard slip resistance | minimum slip rating R10 / pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required |
| FLSK-021 | SKIRTING: vinyl, integral with floor vinyl, coved | |
| WLFI-002 | WALL FINISH: paint, clinical areas | |
| WLFI-101 | SPLASHBACK: vinyl | to basin |
| WLFI-011.06 | WALL FINISH: vinyl, to 2100 AFFL | |
| CLFS-011 | CEILING: flush set, suspended | |
| CLFI-002 | CEILING FINISH: paint, clinical areas | |
| CLCN-031 | CORNICE: square set | |



Joinery

| CODE | DESCRIPTION | GROUP | QTY | COMMENT |
|----------|--|-------|-----|--|
| JOBE-061 | BENCH: 750D, laminate | 0 | 1 | |
| JOBE-221 | BENCH SUPPORT: end panel | 0 | 1 | |
| JOBE-251 | CAP: cable access | 0 | 1 | |
| JODW-041 | DRAWER UNIT: under bench, 4 drawers, equal | 0 | 1 | type and extent of storage to suit service requirements, operational policies for stock centralisation/decanting and infection prevention and control policies |

Issue date: 15.05.2025

Revision: 5

Page: 2 of 4 Room code: MAMMO



Fittings, Furniture and Equipment (FF&E)

| CODE | DESCRIPTION | GROUP | QTY | COMMENT |
|----------|---|-------|-----|--|
| FIBM-019 | WHITEBOARD: fixed, magnetic | 2 | 1 | |
| FIDI-106 | DISPENSER: PPE, disposable gloves, wall mounted | 2 | 1 | |
| FIDI-231 | DISPENSER: paper towel, wall mounted | 2 | 1 | to basin |
| FIDI-241 | DISPENSER: alcohol-based hand rub, wall mounted | 2 | 1 | |
| FIDI-256 | DISPENSER: soap, wall mounted | 2 | 1 | to basin |
| FIDI-261 | DISPENSER: soap, antiseptic, wall mounted | 2 | 1 | to basin |
| FIHR-026 | HOOK: coat | 1 | 2 | optional - for patient property, 1 mounted at 1200H if provided |
| FIHR-101 | BRACKET: suction bottle, wall mounted | 2 | 1 | |
| FIHR-101 | BRACKET: suction bottle, wall mounted | 2 | 1 | |
| FIHR-201 | BRACKET: central processing unit (CPU), under bench/desk | 2 | 1 | |
| FIRT-051 | TRACK: curtain, privacy | 0 | 1 | to entry door |
| FQBS-172 | CHAIR: office, ergonomic, high | 3 | 1 | |
| FQCL-211 | LINEN CARRIER: dirty, single skip | 3 | 1 | |
| FQGE-101 | CURTAIN: privacy screen | 3 | 1 | to entry door |
| FQGE-121 | CLOCK: analogue, battery operated | 3 | 1 | |
| FQSM-057 | PEDESTAL: mobile, 840H nominal, 4 equal wire basket drawers | 3 | 1 | type and extent of storage to suit service requirements, operational policies for stock centralisation/decanting and infection prevention and control policies |
| FQWS-051 | BIN: general waste, 20L | 3 | 1 | to basin |
| HYBA-121 | BASIN: type B, handwashing | 0 | 1 | |
| HYTP-067 | TAPWARE: basin, tap set, wall mounted, lever handles | 0 | 1 | |
| ITNE-071 | TELEPHONE: handset, desktop | 3 | 1 | to workstation |
| ITNE-101 | COMPUTER: single display screen, central processing unit (CPU), keyboard and mouse, desktop | 3 | 1 | |
| ITNE-153 | COMPUTER: central processing unit (CPU), PACS | 3 | 1 | |
| ITNE-172 | DISPLAY SCREEN: computer, PACS | 3 | 1 | |
| ITNE-201 | INPUT DEVICE: keyboard and mouse | 3 | 1 | |
| MMBE-086 | CHAIR: patient | 3 | 1 | |
| MMGE-191 | CANNISTER: suction bottle | 3 | 1 | |
| | <u> </u> | | | |



Major Medical Equipment (MME)

| CODE | DESCRIPTION | GROUP | QTY | COMMENT |
|----------|---|-------|-----|---------|
| MIMM-001 | IMAGING DEVICE: mammography | 2 | 1 | |
| MIMM-011 | CONTROL CONSOLE: mammography, single display screen, keyboard and mouse, control unit | 2 | 1 | |
| MIMM-046 | RACK: mammography paddles, wall mounted | 2 | 1 | |

Issue date: 15.05.2025

Revision: 5

Page: 3 of 4 Room code: MAMMO



| CODE | DESCRIPTION | GROUP | QTY | COMMENT |
|----------|---|-------|-----|---|
| ELGP-105 | GPO: single, wall mounted, cleaner | 0 | 1 | |
| ELGP-201 | GPO: double, wall mounted | 1 | 1 | to workstation, over desk for portable devices |
| ELGP-231 | GPO: double, emergency power, wall mounted | 0 | 2 | to imaging equipment and control console |
| ELGP-231 | GPO: double, emergency power, wall mounted | 0 | 3 | to workstation |
| ELSW-021 | SWITCH: light, dimmer | 0 | 1 | to general room lighting |
| ELSW-043 | SWITCH: light, x-ray in use | 0 | 1 | |
| HYDR-201 | DIRECT CONNECTION: waste water | 0 | 1 | to basin |
| HYTP-451 | DIRECT CONNECTION: water, cold | 0 | 1 | to basin |
| HYTP-453 | DIRECT CONNECTION: water, warm | 0 | 1 | to basin |
| ITCL-191 | BUTTON: emergency, with cancel, wall mounted | 0 | 1 | above services panel |
| ITIN-016 | OUTLET: data, single RJ45, wall mounted | 0 | 2 | to imaging equipment and control console |
| ITIN-036 | OUTLET: data, triple RJ45, wall mounted | 0 | 1 | to workstation |
| ITSE-061 | BUTTON: security, duress, fixed, wall mounted | 0 | 1 | |
| ITSE-166 | INTERCOM: audio, slave, wall mounted | 0 | 1 | optional - inclusion dependent on service requirements and ICT policies |
| LIFX-213 | LIGHT: illuminated sign, x-ray in use | 0 | 1 | to automatically turn on when modality is in use |



Medical Services Panels and Pendants

| CODE | DESCRIPTION | GROUP | QTY | COMMENT |
|----------|--|-------|-----|---------|
| Panel 1 | | | | |
| MMSP-051 | MEDICAL SERVICES PANEL: wall mounted | 0 | 1 | |
| ELGP-116 | GPO: single, on service panel | 0 | 2 | |
| ELGP-146 | GPO: single, emergency power, on service panel | 0 | 2 | |
| ELPR-073 | RCD: residual current device, on services panel | 0 | 2 | |
| ITCL-183 | BUTTON: staff assist, with cancel, on services panel | 0 | 1 | |
| MGAS-042 | OUTLET: oxygen (O2), on services panel | 0 | 1 | |
| MGAS-062 | OUTLET: suction, on services panel | 0 | 1 | |
| MGFP-041 | FLOWMETER: oxygen | 3 | 1 | |
| MGFP-061 | ADAPTER: suction | 3 | 1 | |

Issue date: 15.05.2025

Revision: 5

Page: 4 of 4 Room code: MAMMO