

Room Name	Meeting Room, 20m2		Room Number	MEET-20
Revision	5			
Issue Date	24.06.2022			
BRIEFING				
Briefed Area	20.00 m ²			
Hours of Operation	Available 24 Hours			
Occupancy	Up to 12 seated			
Acoustics	Sound attenuation level high, Acoustic privacy is required.			
Remarks				
Description / Special Requirements	A multipurpose room for staff meetings, education and training activities. Requirement for Hearing Augmentation to be confirmed. Additional Considerations: • Video conferencing systems and AV equipment will be dependent on service requirements and local ICT policies. The display system, sound system, microphone, room and video conferencing control and supporting AV equipment must be carefully considered to provide a cohesive solution for users. Where a camera is provided for video conferencing the furniture layout should be considered to allow for visibility of users within the field of view. • To support video conferencing, decor should be light/neutral and free from busy patterns within the camera view for optimal image quality. • Room booking panels may be provided to suit service/facility approach to room scheduling. • Occupancy will vary, with the total number of people that may be accommodated in the space dependent on furniture layout. • Furniture and layout will vary to suit service requirements. Furniture considerations include provision of stackable chairs and folding tables to support reconfiguration of the layout for flexible use of the space. • Floor boxes for services may be provided to support flexible use of the space. Location to be confirmed to suit service requirements. • Acoustics to be carefully considered to ensure appropriate sound levels, particularly with video conferencing equipment provided, and to reduce noise transfer to/from adjacent areas for privacy and to reduce disruption. Background noise (e.g. from air conditioning) should be minimised. Hard surfaces may be covered to reduce reverberation as required. • Where a meeting room is intended to be used with patients and/or family, additional features for staff safety (e.g. duress buttons, additional egress doors, etc.) may be considered to suit service requirements. An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements. • When used with patients and/or family in mental health settings, an alternative egress door should be provided. Where possible, equipment should be recessed into walls and finishes, fittings, fixtures and furniture should be suitable for mental health patients. All glazing (including external windows) is to be Grade A safety glass to comply with AS/NZS 2208 and AS 1288. • Ready access to a telephone in an adjacent space may be required to answer pagers. • An external outlook is desirable.			
SERVICES				
Electrical	BODY PROTECTED	☐	CARDIAC PROTECTED	☐

Room Name Meeting Room, 20m2

Room Number MEET-20

HVAC

AIRCONDITIONING



AIRCONDITIONING: hepa filtered



AIRCONDITIONING: positive pressure



AIRCONDITIONING: negative pressure



EXHAUST: room exhaust



VENTILATION


Lighting

LIGHTING: colour corrected



LIGHTING: dimmable



LIGHTING: downlights



LIGHTING: downlights, dimmable



LIGHTING: fluorescent/LED, downlights



LIGHTING: fluorescent/LED, flush with ceiling, tamper proof



LIGHTING: fluorescent/LED, general



LIGHTING: indirect


Security / Nurse Call

NURSE CALL SYSTEM


Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	optional lockable
DWPR-001	DOOR PROTECTION: kickplate, to 300 AFFL	
FLCP-006	FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon	
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
DWWH-005	WINDOW	desirable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	
DWWD-004	BLIND: roller	3	1	
FIHR-006	BRACKET: for display screen, wall mounted	2	1	
ITNE-004	CAMERA: video conferencing	3	1	optional, multidirectional, may be provided to support camera in soundbar as required
FQBS-059	CHAIR: meeting rom, stackable	3	12	
FQGE-005	CLOCK: analogue, battery operated	3	1	optional
ITAV-063	COMPUTER: AV system	1	1	
ITAV-006	CONTROL PANEL: AV system, wall mount	3	1	may be wall mounted or on table top
ITAV-062	CONTROL PANEL: room booking system	1	1	optional
ITAV-051	DISPLAY SCREEN: audio visual	3	1	
ITAV-071	MICROPHONE: AV system, ceiling mounted, array	2	1	optional, may be recessed in ceiling

Room Name | Meeting Room, 20m2

Room Number MEET-20

AusHFG code	Description	Group	Qty	Comment
FIJO-194	SHELF: laminate	1	1	
ITAV-090	SOUNDBAR: AV system, camera, speaker and microphone	2	1	functions may be provided by individual items dependent on local ICT policies and service requirements
FQTA-086	TABLE: meeting room, folding	3	2	with services box if floor box provided
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITIN-145	DESK BOX: for power, data, AV, flush mounted, softwired	1	1	optional; to table if floor box provided
ITIN-143	FLOORBOX: for power, data, AV, flush mounted	1	1	optional; services may be wall mounted depending on layout and service requirements
ELGP-203	GPO: double, in floorbox	1	1	optional
ELGP-208	GPO: double, wall mounted	1	4	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITIN-021	OUTLET: data, double RJ45, ceiling mounted	1	1	to microphone array
ITIN-022	OUTLET: data, double RJ45, in floorbox	1	1	optional
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	1 is optional for booking system if provided
ITIN-036	OUTLET: data, triple RJ45, wall mounted	1	2	
ELBO-015	SWITCH: light, single	1	1	