

Room Name	Mortuary - Body Reception		Room Number MOR-BR	
Revision	4			
Issue Date	18.01.2021			
BRIEFING				
Briefed Area	7.00 m <sup>2</sup>			
Hours of Operation	up to 24 Hours			
Occupancy	1 - 2 staff intermittently			
Acoustics				
Remarks				
Description / Special Requirements	room/cool room as well as the checking-o the coroner. This room should be located	out of l on a cover	eceiving bodies from the hospital and checking-in to the hol bodies for release to funeral directors, relatives or for transf corridor that is in close proximity to both the staff-only mortuged parking area. Entry to this area by authorised personnel se proximity.	fer to uary
SERVICES				
General Requirements	BODY PROTECTED		CARDIAC PROTECTED	
Air	AIRCONDITIONING AIRCONDITIONING: positive pressure EXHAUST: room exhaust		AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION	
Lighting	LIGHTING: colour corrected LIGHTING: downlights LIGHTING: fluorescent/LED, downlights LIGHTING: fluorescent/LED, general		LIGHTING: dimmable LIGHTING: downlights, dimmable LIGHTING: fluorescent/LED, flush with ceiling, tamper proof LIGHTING: indirect	
Nurse Call	NURSE CALL SYSTEM		LISTITING. IIIUIIEGI	

## **Room Fabrics**

AusHFG code	Description	Comment
CLTI-008	CEILING: plasterboard, drop-in tiles, prefinished, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	

## Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-212	BULKHEAD: joinery	1	1	plasterboard bulkhead also acceptable
FQBS-018	CHAIR: office, ergonomic	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	2	
FQDW-045	DESK: adj height, 2400W x 750D x 750H nom.	3	1	length to accommodate A3 landscape mortuary register
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-018	DISPENSER: gown	2	1	

AHHA australosion health infrastructure allicore

Page: 1 Print Date: 13/01/2021





**Room Name** 

**Mortuary - Body Reception** 

## **Room Number MOR-BR**

AusHFG code	Description	Group	Qty	Comment
FIDI-021	DISPENSER: mask	2	1	
ITNE-023	PRINTER: networked	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

## **Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	3	emergency power may be provided depending on operational policies and service requirements
LIFX-008	LIGHT: task light, built in	1	2	to underside of overhead cupboards
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	1 outlet for telephone
ELBO-015	SWITCH: light, single	1	1	for task lighting

