



Room Name	Neonatal Bay - Intensive Care, 12m2	Room Number NBICU			
Revision	3				
Issue Date	20.03.17				
BRIEFING					
Briefed Area	12.00 m <sup>2</sup>				
Hours of Operation	24 Hours				
Occupancy	1 baby; 2-3 staff; 1-2 parents				
Acoustics	Sound attenuation level high, Acoustic privacy is required to perimeter walls.				
Remarks					
Description / Special Requirements	A single bay for neonates requiring Intensive Care nursing and medical treatment. The Bay will include provisions for charting and storage. A staff handwash basin (Type A) should be provided within close access of each Bay. An external outlook is required.				
SERVICES					
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = Yes			
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No			
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = Yes LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No			
Nurse Call	NURSE CALL SYSTEM = Yes				

## **Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-006	CORNICE: plasterboard, 90mm to match ceiling finish, paint	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-002	OBSERVATION: internal window, alum/glass, door height, powdercoat	with integral venetians, optional
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin, tiles also acceptable
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	Equal to Acrovyn
DWWH-005	WINDOW	External outlook to the area required

## Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	3	
HYBA-009	BASIN: handwash, Type A, scrub	1	1	in close proximity, refer BHWS-A (similar)
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	

AHHA

aviralision health infrastructure alliance

scriptures: Dissentative St. and and a realize blocker

scriptures: Dissentative St. and and a realize blocker

scriptures: Dissentative St. and and and a realize blocker

Page: 1 Print Date: 20/03/2017





**Room Name** 

Neonatal Bay - Intensive Care, 12m2

**Room Number NBICU** 

AusHFG code	Description	Group	Qty	Comment
DWWD-007	BLIND: venetian, integral	1	1	to observation window if provided
FIHR-019	BRACKET: for suction bottle	2	2	
FQBS-028	CHAIR: visitor, clinical areas	3	1	
FIJO-106	CUPBOARD: drawer unit, 4 equal	1	1	under bench
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	
FIJO-140	CUPBOARD: underbench, single door, adj shelves	1	1	
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	3	over bench
FQGE-009	CURTAIN: bed screen	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	3	
MGFP-004	FLOWMETER: oxygen	3	3	
MMMA-007	INCUBATOR: infant, humidicrib	3	1	
LIFX-013	LIGHT: procedure, ceiling mounted, small	1	1	
MMGE-100	SUCTION BOTTLE	3	3	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	1	to full bay
MMGE-123	TROLLEY: instrument	3	1	

## **Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on services panel
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel
ELGP-209	GPO: double, wall mounted, RCD protected	1	1	
ELGP-123	GPO: emergency power, single, wall mounted	1	12	
ELGP-101	GPO: single, ceiling mounted	1	1	exam light
ELGP-110	GPO: single, wall mounted, cleaner	1	1	to a group of bays
LIFX-008	LIGHT: task light, built in	1	2	under O/H shelving
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	1 outlet for telephone
MGAS-022	OUTLET: medical air (MA), on services panel	1	3	on services panel
MGAS-042	OUTLET: oxygen (O2), on services panel	1	3	on services panel
MGAS-062	OUTLET: suction, on services panel	1	3	on services panel
MMSP-026	SERVICES PANEL: wall mounted	2	1	flush mounted
ELBO-015	SWITCH: light, single	1	1	

AHHA