

Room Name Patient Bay - Critical, 20m2

Room Number PBC-20

Revision

3

Issue Date

20.03.17

BRIEFING
Briefed Area

20.00 m²
Hours of Operation

24 Hours

Occupancy

1 patient, 1-2 visitors, Up to 6-8 staff

Acoustics

Acoustic privacy is required

Remarks
**Description /
Special Requirements**

A Single Bed Bay for patient requiring critical care nursing and medical treatment. Visual access to Staff Station is required. Screen curtains are required for patient privacy. Maximum natural light is required to patient beds.

SERVICES
General Requirements

BODY PROTECTED = No

CARDIAC PROTECTED = Yes

Air

AIRCONDITIONING = Yes

AIRCONDITIONING: hepa filtered = No

AIRCONDITIONING: positive pressure = No

AIRCONDITIONING: negative pressure = No

EXHAUST: room exhaust = No

VENTILATION = No

Lighting

LIGHTING: colour corrected = Yes

LIGHTING: dimmable = No

LIGHTING: downlights = No

LIGHTING: downlights, dimmable = No

LIGHTING: fluorescent, downlights = No

LIGHTING: fluorescent, flush with ceiling, tamper proof = No

LIGHTING: fluorescent, general = No

LIGHTING: indirect = No

Nurse Call

NURSE CALL SYSTEM = Yes

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-003	OBSERVATION: internal window, alum/glass, double glazed, integral venetian blind, powdercoat	to partition walls
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin, tiles also acceptable
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	Equal to 'Acrovyn'
DWWH-005	WINDOW	desirable

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	4	on tandem pendant
HYBA-009	BASIN: handwash, Type A, scrub	1	1	refer BHWS-A (similar)
MMBE-013	BED: patient, ICU, electric	3	1	

Room Name | Patient Bay - Critical, 20m2

Room Number PBC-20

AusHFG code	Description	Group	Qty	Comment
FQCW-004	BIN: waste, clinical, 120L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-043	BIN: waste, sharps, on trolley	3	1	
DWWD-007	BLIND: venetian, integral	1	2	to windows, controls to both sides
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	
FIHR-013	BRACKET: for monitor, ECG	3	1	mounted on pendant
FIHR-016	BRACKET: for sharps bin	2	1	mounted to trolley
MMHA-001	CARRIER: suction bottle	3	1	mobile
FQBS-022	CHAIR: recliner, clinical	3	1	patient - intermittent use
FQBS-031	CHAIR: visitor, patient, stackable	3	1	
ITCL-016	CLOCK: clock system slave, analogue	1	1	ceiling mounted, master clock system
FQGE-009	CURTAIN: bed screen	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
ITBU-012	DISPLAY SCREEN: patient entertainment system	1	1	
MMGE-033	FLOWCHART STAND: mobile	3	1	
MGFP-002	FLOWMETER: medical air	3	2	on tandem pendant
MGFP-004	FLOWMETER: oxygen	3	4	on tandem pendant
LIFX-027	LIGHT: examination, ceiling mounted	1	1	
MMGE-048	LINEN CARRIER: dirty, single	3	1	
MMHA-005	MONITOR: patient, cardiac	3	1	
MMSP-023	PENDANT: single, power and data	1	1	
MMSP-020	PENDANT: tandem, wet and dry combination (fixed or adjustable height)	1	1	
MMGE-096	STATION: dialysis	1	1	with RO water & tundish drain
FQBS-052	STOOL: mobile, high, adj height	3	1	for staff
MMGE-100	SUCTION BOTTLE	3	4	on tandem pendant
FQTA-013	TABLE: overbed	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	to staff work area
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	1	
FQSM-016	TROLLEY	3	1	
FIBM-018	WHITEBOARD: fixed	2	1	600mm x 600mm

Engineering Services

Room Name | Patient Bay - Critical, 20m2

Room Number PBC-20

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on tandem pendant, + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on tandem pendant, + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on tandem pendant, + indicator button & light
HYDR-006	DRAIN: tundish	1	1	
ELGP-204	GPO: double, on pendant	1	2	on single pendant
ELGP-208	GPO: double, wall mounted	1	2	to walls
ELGP-223	GPO: emergency power, double, wall mounted	1	1	to dialysis station
ELGP-121	GPO: emergency power, single, on pendant	1	12	on tandem pendant
ELGP-101	GPO: single, ceiling mounted	1	3	for display screen, proc light, clock
ELGP-104	GPO: single, on pendant	1	12	on tandem pendant
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on tandem pendant, call button on the handset
LIFX-017	LIGHT: night light	1	1	
ITIN-024	OUTLET: data, double RJ45, on pendant	1	1	on single pendant
ITIN-024	OUTLET: data, double RJ45, on pendant	1	1	on tandem pendant
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ITIN-014	OUTLET: data, single RJ45, on pendant	1	1	on tandem pendant, for monitor communications with associated cabling and connections; verify outlet type/s with monitor selected
ITIN-070	OUTLET: MATV	1	1	
MGAS-021	OUTLET: medical air (MA), on pendant	1	2	on tandem pendant
MGAS-041	OUTLET: oxygen (O2), on pendant	1	4	on tandem pendant
HYTP-015	OUTLET: reverse osmosis (RO) water	1	1	
MGAS-051	OUTLET: scavenge, on pendant	1	1	on tandem pendant
MGAS-061	OUTLET: suction, on pendant	1	4	on tandem pendant
ELPR-006	RCD: residual current device	1	1	on tandem pendant