

Room Name	Patient Bay - Specimen Collection		Room Number PBSC
Revision	4		
Issue Date	24.06.2022		
BRIEFING			
Briefed Area	9.00 m ²		
Hours of Operation	8am to 6pm, daily		
Occupancy	1 patient, 1 staff		
Acoustics			
Remarks			
Description / Special Requirements	<p>A Patient Bay used for the collection of specimens to be transferred to a laboratory for testing.</p> <p>Additional Considerations:</p> <ul style="list-style-type: none"> • Ready access to a handwashing basin is required. • Ready access may be required to a pneumatic tube bay that is in a staff supervised area. • Recliner must be able to lay flat to support the patient in the event of an adverse reaction (e.g. fainting). • A desk may be provided in lieu of Workstation on Wheels depending on operational model. • An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements. • A risk assessment should be undertaken to inform staff safety requirements with adjoining cubicles which may require adjustments to the design and/or operational strategies, such as the use of mobile duress systems. • Refer to the Pathology HPU for paediatric requirements. 		
SERVICES			
Electrical	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
HVAC	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Security / Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>	

Room Name | Patient Bay - Specimen Collection

Room Number PBSC

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-020	WALL FINISH: vinyl, to 1500 AFFL	
WLPR-006	WALL PROTECTION: corner guards	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQSN-007	BIN: storage bins, wire mesh, stainless steel	1	1	extent and type of storage to be based on service requirements and local infection control policies
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-044	BIN: waste, sharps, wall mounted	3	1	on trolley; may be wall mounted or mobile
FIHR-016	BRACKET: for sharps bin	2	1	on trolley
MMBE-094	CHAIR: recliner, clinical, phlebotomy	3	1	electric, height adjustable and able to lie flat, electric examination couch may also be provided
FQBS-028	CHAIR: visitor, clinical areas	3	1	optional
ITNE-008	COMPUTER: for workstation on wheels	3	1	
FQGE-010	CURTAIN: privacy screen	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIHR-026	HOOK: coat	1	2	optional, prioritize lower hook for wheelchair users if only one hook provided
LIFX-027	LIGHT: examination, ceiling mounted	1	1	optional
FIHR-033	PANEL: for storage bins, wall mount	1	1	
FQGE-056	PRINTER: desktop, labels	3	1	optional, on WOW
FQBS-051	STOOL: mobile, adj height	3	1	
FIRT-031	TRACK: curtain, privacy	1	1	
MMGE-189	TROLLEY: phlebotomy 600W x 490D x 900H nominal	3	1	with drop down shelf
MMGE-164	WORKSTATION ON WHEELS: clinical, mobile	3	1	a desk may be provided depending on operational model

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELPR-001	BODY PROTECTED ELECTRICAL AREA	1	1	
ITSE-006	BUTTON: duress, fixed	1	1	
ITCL-004	BUTTON: nurse call, emergency	1	1	

Room Name | **Patient Bay - Specimen Collection**
Room Number PBSC

AusHFG code	Description	Group	Qty	Comment
ITCL-008	BUTTON: nurse call, staff assist	1	1	
ELGP-208	GPO: double, wall mounted	1	1	
ELGP-101	GPO: single, ceiling mounted	1	1	optional, to exam light
ELGP-109	GPO: single, wall mounted	1	1	to chair
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ELPR-006	RCD: residual current device	1	1	
ELBO-015	SWITCH: light, single	1	1	optional, to exam light