



Room Name	Patient Bay - Resuscitation, 25m2	Room Number PBTR-R				
Revision	4					
Issue Date	20.03.17					
BRIEFING						
Briefed Area	25.00 m ²					
Hours of Operation	24 Hours					
Occupancy	1 patient; 4 - 5 staff					
Acoustics	•					
Remarks						
Description / Special Requirements	A Patient Bed Bay for assessment, resuscitation and treatment of patients with critical conditions, located within the Emergency Unit. The Bay may have partition side walls and a bench used for preparation and write-up. Resuscitation and diagnostic equipment should be located in close proximity which may include ventilator, cardiac pacemaking equipment and mobile X-ray machine.					
SERVICES						
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = Yes				
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No				
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No				
Nurse Call	NURSE CALL SYSTEM = Yes					

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin & above bench
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	As required, Equal to 'Acrovyn'
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	As required, equal to 'Acrovyn'

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	3	on pendant
HYBA-009	BASIN: handwash, Type A, scrub	1	1	refer BHWS-A (similar)
MMBE-011	BED: patient, emergency, electric	3	1	
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	open under part
FQSN-006	BIN: storage bins, for wall mounted panel	3	3	for storage on louvred panel
FQCW-004	BIN: waste, clinical, 120L	3	1	

Page: 1 Print Date: 20/03/2017







Room Name

Patient Bay - Resuscitation, 25m2

Room Number PBTR-R

AusHFG code	Description	Group	Qty	Comment
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FIHR-016	BRACKET: for sharps bin	2	1	on trolley
FQBS-019	CHAIR: office, ergonomic, high	3	1	for staff use
ITCL-016	CLOCK: clock system slave, analogue	1	1	
ITCL-022	CLOCK: clock system slave, elapsed time	1	1	beside analogue
ITNE-007	COMPUTER: desktop, with display screen	3	1	to bench, optional
FIJO-101	CUPBOARD: bench mount, single door, lockable	1	1	with drug safe
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	2	
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	2	over bench, drug storage
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	3	over bench, storage
FQGE-009	CURTAIN: bed screen	3	1	
FQGE-010	CURTAIN: privacy screen	3	2	
MMHA-002	DEFIBRILLATOR	3	1	on resuscitation trolley
MMGE-031	DIAGNOSTIC SET: wall mounted	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	2	on pendant
MGFP-004	FLOWMETER: oxygen	3	3	on pendant
MMGE-036	FRIDGE: drugs, underbench	3	1	
MMGE-039	HANGER: IV, for ceiling track	1	1	optional, may be attached to pendant
MMSP-029	LIGHT: operating, single, 550 diam nom.	1	1	
MMHA-030	MONITOR: patient, cardiac, pendant mounted	3	1	
FIHR-033	PANEL: for storage bins, wall mount	1	2	for storage, above bench
MMSP-018	PENDANT: single, wet and dry combination (fixed or adjustable height)	1	1	
MMGE-088	SAFE: dangerous drugs, small	1	1	in cupboard
MMGE-100	SUCTION BOTTLE	3	3	on pendant
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	to bench
FIRT-020	TRACK: ceiling mounted, IV	1	1	optional
FIRT-023	TRACK: curtain, bedscreen, L shaped	1	1	
MMHA-027	TROLLEY: resuscitation, adult	3	1	
MMGE-154	VIEWER: X-ray, 3 screen	1	1	recessed

Engineering Services



Page: 2 Print Date: 20/03/2017





Room Name

Patient Bay - Resuscitation, 25m2

Room Number PBTR-R

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	on pendant + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on pendant + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on pendant + indicator button & light
ELGP-223	GPO: emergency power, double, wall mounted	1	2	to bench
ELGP-223	GPO: emergency power, double, wall mounted	1	1	for resus trolley
ELGP-121	GPO: emergency power, single, on pendant	1	16	on pendant (2-UPS)
ELGP-106	GPO: single, special, for equipment	1	4	theatre light, clocks, XRV
ELGP-109	GPO: single, wall mounted	1	2	fridge, diagnostic set
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	call button on the handset
LIFX-008	LIGHT: task light, built in	1	1	under O/H shelves/ cupboards
ITIN-024	OUTLET: data, double RJ45, on pendant	1	1	on pendant
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	1 outlet for telephone
ITIN-014	OUTLET: data, single RJ45, on pendant	1	1	on pendant, optional, for monitor communications with associated cabling and connections; verify outlet type/s with monitor selected
MGAS-021	OUTLET: medical air (MA), on pendant	1	2	on pendant
MGAS-031	OUTLET: nitrous oxide (N2O), on pendant	1	1	on pendant, optional
MGAS-041	OUTLET: oxygen (O2), on pendant	1	3	on pendant
MGAS-051	OUTLET: scavenge, on pendant	1	1	on pendant, optional, if N2O provided
MGAS-061	OUTLET: suction, on pendant	1	3	on pendant
ELBO-015	SWITCH: light, single	1	1	

AHHA
averatesian heelth infrastructure silicoce
controllecture to March and Annual Ann

Page: 3 Print Date: 20/03/2017