

| Room Name                             | Pharmacy - Preparation Room, Nor  | ı-Ase        | eptic Room Number PHA-PR                                    |  |
|---------------------------------------|---|--------------|---|--|
| Revision                              | 4   |              |   |  |
| Issue Date                            | 26.04.2021  |              |   |  |
| BRIEFING                              |   |              |   |  |
| Briefed Area                          | 12.00 m <sup>2</sup>  |              |   |  |
| Hours of Operation                    | 8am to 8pm, daily   |              |   |  |
| Occupancy                             | Up to 2 Staff   |              |   |  |
| Acoustics                             | Op 10 2 Gtail   |              |   |  |
| Remarks                               |   |              |   |  |
| Description /<br>Special Requirements | The Preparation Room provides a dedicated area for the extemporaneous preparation and compounding of non-aseptically prepared products and cleaning of equipment as required. The Preparation Room should be located in close proximity to the dispensing area. |              |   |  |
| SERVICES                              |   |              |   |  |
| Electrical                            | BODY PROTECTED  |              | CARDIAC PROTECTED   |  |
| HVAC                                  | AIRCONDITIONING   | <b>√</b>     | AIRCONDITIONING: hepa filtered                              |  |
|                                       | AIRCONDITIONING: positive pressure  |              | AIRCONDITIONING: negative pressure                          |  |
|                                       | EXHAUST: room exhaust   |              | VENTILATION   |  |
| Lighting                              | LIGHTING: colour corrected  |              | LIGHTING: dimmable  |  |
|                                       | LIGHTING: downlights  |              | LIGHTING: downlights, dimmable                              |  |
|                                       | LIGHTING: fluorescent/LED, downlights   |              | LIGHTING: fluorescent/LED, flush with ceiling, tamper proof |  |
|                                       | LIGHTING: fluorescent/LED, general  | $\checkmark$ | LIGHTING: indirect  |  |
| Security / Nurse Call                 | NURSE CALL SYSTEM   |              |   |  |

## **Room Fabrics**

| AusHFG code | Description   | Comment   |  |  |
|-------------|---|---|--|--|
| CLFS-006    | CEILING: plasterboard, flush set, suspended, paint, washable              |   |  |  |
| CLCN-008    | CORNICE: square set flush between wall and ceiling, paint                 |   |  |  |
| DWGL-003    | DOOR: 910mm c/o, single leaf, half glazed, solid core/safety glass, paint |   |  |  |
| DWPR-005    | DOOR PROTECTION: protection plate to 900 AFFL                             |   |  |  |
| FLVY-007    | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant             | floor finish must be minimum<br>slip rating R10; pendulum P3<br>or agreed equivalent to extend<br>under basin |  |  |
| FLSK-010    | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished                     |   |  |  |
| WLWA-004    | WALL FINISH: paint, acrylic, washable                                     |   |  |  |
| WLWA-010    | WALL FINISH: splashback, vinyl  |   |  |  |
| WLWA-020    | WALL FINISH: vinyl, to 1500 AFFL  |   |  |  |
|             |   |   |  |  |

## Fittings, Furniture and Equipment (FF&E) Items

| AusHFG code | Description                              | Group | Qty | Comment   |
|-------------|--|-------|-----|---|
| HYBA-010    | BASIN: handwash, Type B                  | 1     | 1   |   |
| FIJO-020    | BENCH: 600D, open under, laminate finish | 1     | 1   | may be height adjustable<br>item depending on service<br>requirements |

AHIA

Page: 1 Print Date: 21/04/2021





Room Name

Pharmacy - Preparation Room, Non-Aseptic

**Room Number PHA-PR** 

| AusHFG code | Description  | Group | Qty | Comment  |
|-------------|--|-------|-----|--|
| FIJO-059    | BENCH TOP: 600D, joinery under, laminate finish                  | 1     | 2   |  |
| FQCW-016    | BIN: waste, general, 20L   | 3     | 1   | to basin   |
| FQCW-019    | BIN: waste, general, 50L   | 3     | 1   | quantity and type of bins<br>to be based on local waste<br>management policies |
| FQCW-065    | BIN: waste, pharmaceutical 50L                                   | 3     | 1   | quantity and type of bins<br>to be based on local waste<br>management policies |
| FQCW-044    | BIN: waste, sharps, wall mounted                                 | 3     | 1   |  |
| FIHR-016    | BRACKET: for sharps bin  | 2     | 1   |  |
| FIJO-212    | BULKHEAD: joinery  | 1     | 2   |  |
| FIJO-136    | CUPBOARD: underbench, double door, adj shelves, lockable         | 1     | 3   |  |
| FIJO-141    | CUPBOARD: underbench, single door, adj shelves, lockable         | 1     | 1   |  |
| FIJO-148    | CUPBOARD: wall mount, double door, glazed, adj shelves, lockable | 1     | 3   |  |
| FIJO-159    | CUPBOARD: wall mount, single door, glazed, adj shelves, lockable | 1     | 1   |  |
| FIDI-014    | DISPENSER: disposable glove                                      | 2     | 1   | to basin   |
| FIDI-025    | DISPENSER: paper/hand towel                                      | 2     | 1   | to basin   |
| FIDI-030    | DISPENSER: soap  | 2     | 1   | to basin   |
| FIDI-031    | DISPENSER: soap antiseptic                                       | 2     | 1   | to basin   |
| MEEX-013    | FUME CUPBOARD  | 1     | 1   |  |
| MMGE-185    | SCALES: digital, benchtop  | 3     | 2   |  |
| HYBA-069    | SINK: single, with drainer, 930mmL                               | 1     | 1   |  |
| HYTP-037    | TAPWARE: mixer, elbow levers                                     | 1     | 1   | to basin   |
| HYTP-040    | TAPWARE: mixer, sink, accessible                                 | 1     | 1   |  |
| FQSM-016    | TROLLEY  | 3     | 1   | optional   |

## **Engineering Services**

| AusHFG code | Description                 | Group | Qty | Comment   |
|-------------|-----------------------------|-------|-----|---|
| ELGP-208    | GPO: double, wall mounted   | 1     | 4   | provision of emergency power<br>to be determined based on<br>service requirements |
| LIFX-008    | LIGHT: task light, built in | 1     | 2   | under wall mounted joinery  |
| ELBO-015    | SWITCH: light, single       | 1     | 3   | 1 x general room lighting, 2 x task lights  |

Page: 2 Print Date: 21/04/2021