

Room Name	Patient Bay - Holding, Chair		Room Number PT-HOLD-A
<b>Revision</b>	6		
<b>Issue Date</b>	31.01.2024		
<b>BRIEFING</b>			
<b>Briefed Area</b>	6.50 m <sup>2</sup>		
<b>Hours of Operation</b>	up to 24 Hours		
<b>Occupancy</b>	1 patient, 1 visitor, 1-2 staff intermittently		
<b>Acoustics</b>			
<b>Remarks</b>			
<b>Description / Special Requirements</b>	<p>A Patient Bay - Holding provides facilities for patient holding and preparation prior to examination, diagnostic imaging, treatment, procedures or surgery. A handwashing basin will be provided close by to be shared between multiple bays. Staff observation is required and, where possible, a clear line of sight from a staff station is to be provided. Close access to a patient toilet is required.</p> <p><u>Additional Considerations:</u></p> <ul style="list-style-type: none"> <li>The configuration of the Medical Services Panel (MSP), including medical gases, power and data, will be dependent on service requirements. Data provision is to take into consideration the increasing demand and sophistication of information systems and the technological development of monitoring equipment.</li> <li>The requirement for fixed wall mounted patient monitoring will be dependent on service requirements. A patient monitor may be located on the left or right side of bedhead depending on monitor functionality and staff workflows. Appropriate wall supports are required for mounting the bracket where a monitor is provided.</li> <li>Where patient monitoring is provided, criticality of monitoring is to be assessed. Provision of emergency/standby power or UPS is to be confirmed to suit site and service requirements. Confirmation to be based on risk assessment considering the impact of a power outage on patient care/safety.</li> <li>Facilities to accommodate bariatric patients within a select number of bays, including accommodating bariatric recliners, is to be considered to ensure sufficient amenity is provided. Provision will be dependent on service and patient cohort requirements.</li> <li>Depending on service requirements, enclosed holding bays may be provided. Where a Patient Bay is to be enclosed, additional area is required to accommodate a dedicated handwashing basin and circulation at the door. Observation windows may be required and the extent of glazing to be provided is to suit requirements for staff supervision.</li> <li>PPE may be consolidated between multiple bays. Provision of PPE and placement throughout the overall department will be dependent on local infection control policies.</li> <li>A mobile sharps bin will be shared between multiple bays as required. Where use of sharps is frequent, a wall mounted bin sharps bin may be considered.</li> <li>Electronic Medical Record (EMR) management may be performed on a wirelessly connected workstation on wheels (WOW) that is shared between a number of bays. Ensure circulation space is sufficient for bedside and bed end data entry. Parking for WOWs and facilities for battery charging are required to support this model of care. Alternative configurations, such as wall mounted monitors in bays, may be considered depending on local ICT policies.</li> <li>Patient entertainment systems may be considered depending on anticipated length of stay within the holding bay and patient cohort requirements (e.g. paediatrics). Solutions may include individual systems provided to each bay (with integration to patient handset for audio and content control), a central display screen visible from multiple bays, or portable solutions, such as tablets, brought to patients as needed.</li> <li>Operational models for handling patient belongings are to be considered. Close proximity to patient lockers or other secure property storage may be required where belongings are not to be kept with the patient.</li> <li>Depending on anticipated length of stay and pre-procedure requirements, local control of lighting within the bay may be provided to allow patients to dim/adjust lighting levels to increase comfort.</li> <li>Access to natural light is required and an external outlook is recommended.</li> </ul>		
<b>SERVICES</b>			
<b>Electrical</b>	BODY PROTECTED	<input checked="" type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
<b>HVAC</b>	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION <input type="checkbox"/>
<b>Lighting</b>	LIGHTING: colour corrected	<input checked="" type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>

**Room Name Patient Bay - Holding, Chair**
**Room Number PT-HOLD-A**
**Security / Nurse Call**

LIGHTING: fluorescent/LED, downlights

☐

LIGHTING: fluorescent/LED, flush with ceiling, tamper proof

☐

LIGHTING: fluorescent/LED, general

☐

LIGHTING: indirect

☐

NURSE CALL SYSTEM

☒
**Room Fabrics**

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	acoustic tiles are also acceptable
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLPR-001	WALL PROTECTION: bed protection wall panel	

**Fittings, Furniture and Equipment (FF&E) Items**

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	1	
FQSN-006	BIN: storage bins, for wall mounted panel	3	4	type and size of bins dependant on items to be stored
FIHR-019	BRACKET: for suction bottle	2	1	
MMBE-091	CHAIR: recliner, clinical, electric	3	1	
FQBS-030	CHAIR: visitor, patient	3	1	optional
ITNE-008	COMPUTER: for workstation on wheels	3	1	shared between multiple bays
FQGE-010	CURTAIN: privacy screen	3	1	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	1	
FIHR-033	PANEL: for storage bins, wall mount	1	1	type and extent of storage dependant on operational policies for stock centralisation/decanting and infection prevention and control policies
MMGE-100	SUCTION BOTTLE	3	1	
FIRT-047	TRACK: curtain, privacy, U shaped	1	1	
MMGE-164	WORKSTATION ON WHEELS: clinical, mobile	3	1	shared between multiple bays

**Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	with indicator button and light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel, with indicator button and light

**Room Name** | **Patient Bay - Holding, Chair**
**Room Number** PT-HOLD-A

AusHFG code	Description	Group	Qty	Comment
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel, with indicator button and light
ELGP-208	GPO: double, wall mounted	1	1	for patient's own devices
ELGP-223	GPO: emergency power, double, wall mounted	1	1	optional, for patient monitoring
ELGP-122	GPO: emergency power, single, on services panel	1	5	type and quantity to suit service requirements
ELGP-109	GPO: single, wall mounted	1	1	low, for patient recliner
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on services panel
LIFX-032	LIGHT: downlight, examination, ceiling mounted	1	1	optional, provision dependant on service requirements; articulated examination light is also acceptable
ITIN-025	OUTLET: data, double RJ45, on services panel	1	2	quantity to suit service requirements
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	optional, for patient monitoring
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	
MGAS-062	OUTLET: suction, on services panel	1	1	
ELPR-006	RCD: residual current device	1	2	on services panel
MMSP-026	SERVICES PANEL: wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	1	optional, to services panel, for examination downlight if provided