

Room Name	Pantry	Room Number PTRY
Revision	6	
Issue Date	31.01.2024	
BRIEFING		
Briefed Area	9.00 m ²	
Hours of Operation	Up to 24 Hours	
Occupancy	1-2 staff intermittently	
Acoustics		
Remarks		
Description / Special Requirements	<p>The Pantry is for staff preparing and/or heating refreshments and snacks for patients, washing utensils and crockery or temporarily storing dirty items for collection, storing food and drink and disposing of food waste. This room may be shared between multiple units depending on service requirements.</p> <p><u>Additional Considerations:</u></p> <ul style="list-style-type: none"> If food re-thermalisation trolleys are to be located in this room during meal times an additional 2m2 per trolley will be required as well as appropriate power outlets. Refer to Bay - Meal Trolley (BMT) for requirements. Local food preparation regulations and infection control policies may require a Type B hand wash basin, separate to the sink, to be included in the room or may allow for it to be located nearby. Fridge dimensions will vary depending on selection and service requirements; clear area provided for the fridge is to allow for adequate ventilation and full opening of door. Where double door fridges are provided, additional area will be required. If an instantaneous boiling water tap/unit is provided, access should be restricted to the water unit e.g. within a cupboard. If system is located within a joinery unit, ensure appropriate ventilation is provided. Provision and type of ice machine will be dependent on service requirements and local infection prevention and control policies. Where ice machine is provided, ensure adequate support to bench for weight of appliance. Where tea service is provided the height of the hot water dispenser is to be considered to ensure large kettles can be filled easily. Size, type and quantity of waste bins is dependent on environmental management policies and service requirements. Where a facility has additional waste streams, beyond the general waste and comingled recycling streams indicatively shown in this Standard Component, additional area may be required to accommodate the receptacles. Depending on frequency of waste removal and anticipated traffic, bin sizes may be larger in high use areas or as guided by local waste management policies. Joinery to conceal bins may be provided depending on infection prevention and control policies. Storage of nutritional supplements may require a lockable cupboard and will be dependent on service requirements. Temperature of fridge may need to be monitored. A data outlet, or alternative connection to suit project/equipment requirements, may be required for connection the Building Management System (BMS) depending on service requirements. Controlled, staff-only access may be required if this room is provided in a public or patient care area. 	
SERVICES		
Electrical	BODY PROTECTED <input type="checkbox"/>	CARDIAC PROTECTED <input type="checkbox"/>
HVAC	AIRCONDITIONING <input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered <input type="checkbox"/>
	AIRCONDITIONING: positive pressure <input type="checkbox"/>	AIRCONDITIONING: negative pressure <input type="checkbox"/>
	EXHAUST: room exhaust <input type="checkbox"/>	VENTILATION <input type="checkbox"/>
Lighting	LIGHTING: colour corrected <input type="checkbox"/>	LIGHTING: dimmable <input type="checkbox"/>
	LIGHTING: downlights <input type="checkbox"/>	LIGHTING: downlights, dimmable <input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights <input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof <input type="checkbox"/>
	LIGHTING: fluorescent/LED, general <input checked="" type="checkbox"/>	LIGHTING: indirect <input type="checkbox"/>
Security / Nurse Call	NURSE CALL SYSTEM <input type="checkbox"/>	

Room Fabrics

Room Name | **Pantry**
Room Number PTRY

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	with hold open device to support trolley movement as required
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
FLVY-003	FLOOR FINISH: vinyl, seamless, coved, non slip	floor finish must be minimum slip rating R10/pendulum P3 or agreed equivalent
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	to bench with sink, to basin

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-011	BASIN: handwash, Type C	1	1	
FIJO-069	BENCH TOP: 750D, joinery under, laminate finish	1	1	minimum depth 600mm; where an ice machine is provided the depth may need to increase to accommodate appliance
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-019	BIN: waste, general, 50L	3	1	size, type and quantity of bins dependent on local waste management policies
FQCW-062	BIN: waste, recycling, comingled, 50L	3	1	size, type and quantity of bins dependent on local waste management policies
HYGE-003	BOILING/CHILLED WATER UNIT: Combination	1	1	ensure adequate ventilation in joinery
FIJO-212	BULKHEAD: joinery	1	2	plasterboard bulkhead is also acceptable
FIJO-104	CUPBOARD: drawer unit, 3 equal	1	1	
FIJO-163	CUPBOARD: tall, single microwave	1	1	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	1	
FIJO-156	CUPBOARD: wall mount, single door, adj shelves	1	1	
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FQCA-015	DISPENSER: ice, potable	1	1	optional; item to comply with infection control requirements
FIDI-025	DISPENSER: paper/hand towel	2	2	1 to basin, 1 to sink
FIDI-030	DISPENSER: soap	2	2	1 to basin, 1 to sink
FQCA-027	FRIDGE: commercial, floor standing, single door	3	1	Clear area for fridge to allow for adequate ventilation and full opening of door. May be connected to BMS for temperature monitoring depending on service requirements,
FQCA-067	OVEN: microwave, domestic	3	1	

Room Name | **Pantry**
Room Number PTRY

AusHFG code	Description	Group	Qty	Comment
HYBA-069	SINK: single, with drainer, 930mmL	1	1	
HYTP-029	TAPWARE: boiling/chilled water unit (comb)	1	1	instant hot/cold water tap to sink; high/gooseneck tap may be required where large kettles are to be filled for tea service
HYTP-040	TAPWARE: mixer, sink, accessible	1	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	over bench
ELGP-109	GPO: single, wall mounted	1	3	1 to fridge, 1 to microwave, 1 to boiling/ chilled water unit
HYTP-008	OUTLET: cold water	1	1	to boiling/ chilled water unit
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	optional, to fridge, for temperature monitoring as required
ITSE-038	READER: access control, general	1	1	optional, dependent on security requirements and location of room
ELBO-015	SWITCH: light, single	1	1	