

Room Name	Reception, 10m2		Room Number	RECP-10
Revision	6			
Issue Date	24.06.2022			
BRIEFING				
Briefed Area	10.00 m ²			
Hours of Operation	8am to 6pm, daily, dependent on function of unit			
Occupancy	1 staff			
Acoustics	Sound attenuation level - Medium; acoustic privacy required.			
Remarks				
Description / Special Requirements	A Reception area where visitors to a Unit can be received and directed to their destination or to a Waiting Area. The Reception may also act as an administrative base as well as controlling access to the Unit. Additional Considerations: • Dependent on location, security glazing or shutters may be required. • A recessed area for front access by wheelchair users is typically required. Depending on check in requirements at Reception, a set down area for visual access only may be sufficient. • Adjustable height workstations may be provided in line with WHS policies and access for disabled staff working within the Reception area is to be considered. • CCTV monitor, intercom and door release buttons linked to entry points may be required for access control depending on location. • A desktop printer and labels printer may be provided as required. Printing, scanning and photocopying facilities may be consolidated with ready access from Reception to suit service requirements. • Swipe card access to reception may be provided to suit security requirements.			
SERVICES				
Electrical	BODY PROTECTED	☐	CARDIAC PROTECTED	☐
HVAC	AIRCONDITIONING	☒	AIRCONDITIONING: hepa filtered	☐
	AIRCONDITIONING: positive pressure	☐	AIRCONDITIONING: negative pressure	☐
	EXHAUST: room exhaust	☐	VENTILATION	☐
Lighting	LIGHTING: colour corrected	☐	LIGHTING: dimmable	☐
	LIGHTING: downlights	☐	LIGHTING: downlights, dimmable	☐
	LIGHTING: fluorescent/LED, downlights	☐	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	☐
	LIGHTING: fluorescent/LED, general	☒	LIGHTING: indirect	☐
Security / Nurse Call	NURSE CALL SYSTEM	☐		

Room Name | Reception, 10m2

Room Number RECP-10

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLGE-001	CEILING: plasterboard, bulkhead, paint	
CLCN-009	CORNICE: wall trim fixing	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	
DWPR-001	DOOR PROTECTION: kickplate, to 300 AFFL	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	carpet tiles are also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-051	BENCH TOP: 450D, joinery under	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FIJO-099	CAC: cable access cap	3	1	
FQBS-018	CHAIR: office, ergonomic	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	dual screens may be provided to suit service requirements
FIJO-106	CUPBOARD: drawer unit, 4 equal	1	1	
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	
FIJO-182	JOINERY UNIT: reception desk	1	1	
FQSM-007	PEDESTAL: mobile, drawer unit, 660H	3	1	
ITNE-023	PRINTER: networked	3	1	optional
WLPT-014	SCREEN: acoustic, privacy, safety glass	1	3	optional
WLPT-015	SCREEN: security, safety glass, with communication slot and pass through	1	2	optional
ITNE-049	TELEPHONE: handset, desktop	3	1	
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITSE-006	BUTTON: duress, fixed	1	1	
ELBO-003	CONTROL PANEL: lighting	1	1	optional
MEGE-007	CONTROL PANEL: temperature	1	1	optional
ITSE-025	DOOR RELEASE: access control, remote activation	1	1	optional, to external entry and/or unit entry as required
ELGP-208	GPO: double, wall mounted	1	3	1 x for BYO devices, to be located above desk for easy access, location of outlets to meet local operational/WHs requirements
ELGP-223	GPO: emergency power, double, wall mounted	1	1	extent of emergency power to be determined based on service requirements, location of outlets to meet local operational/WHs requirements

Room Name | **Reception, 10m2****Room Number RECP-10**

AusHFG code	Description	Group	Qty	Comment
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	
ITIN-036	OUTLET: data, triple RJ45, wall mounted	1	1	location of outlets to meet local operational/WHS requirements
ITSE-038	READER: access control, general	1	1	optional
ELBO-015	SWITCH: light, single	1	1	