



| Room Name | Staff Room, 18m2 | Room Number SRM-18 | | | |
|---------------------------------------|---|--|--|--|--|
| Revision | 5 | | | | |
| Issue Date | 20.03.17 | | | | |
| BRIEFING | | | | | |
| Briefed Area | 18.00 m ² | | | | |
| Hours of Operation | 24 Hours | | | | |
| Occupancy | Up to 8-10 seated minimum | | | | |
| Acoustics | Sound attenuation level high, Acoustic privacy is required. | | | | |
| Remarks | | | | | |
| Description / Special Requirements | The Staff Room is a shared facility for staff to use for respite, rest and relaxation during meal breaks, especially where it is difficult for staff to use common facilities particularly at night. Facilities for food and beverage preparation and storage should be provided. Where possible the Staff Room should be shared between two Inpatient Units or one per floor in a larger facility and located separate from public/patient access areas. An external outlook is desirable. | | | | |
| SERVICES | | | | | |
| General Requirements | BODY PROTECTED = No | CARDIAC PROTECTED = No | | | |
| Air | AIRCONDITIONING = Yes | AIRCONDITIONING: hepa filtered = No | | | |
| | AIRCONDITIONING: positive pressure = No | AIRCONDITIONING: negative pressure = No | | | |
| | EXHAUST: room exhaust = No | VENTILATION = No | | | |
| Lighting | LIGHTING: colour corrected = No | LIGHTING: dimmable = No | | | |
| | LIGHTING: downlights = No | LIGHTING: downlights, dimmable = No | | | |
| | LIGHTING: fluorescent, downlights = No | LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No | | | |
| | LIGHTING: fluorescent, general = Yes | LIGITTING. IIIQIIECI = NO | | | |
| Nurse Call | NURSE CALL SYSTEM = Yes | | | | |
| | | | | | |

Room Fabrics

| AusHFG code | Description | Comment |
|-------------|--|--|
| CLTI-002 | CEILING: acoustic, drop-in tiles, 600 x 1200 | |
| CLGE-001 | CEILING: plasterboard, bulkhead, paint | Between above bench joinery and ceiling. |
| CLCN-002 | CORNICE: aluminium, 24mm shadow angle, powdercoat | |
| DWGL-005 | DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint | lockable |
| DWPR-001 | DOOR PROTECTION: kickplate, to 300 AFFL | |
| FLCP-006 | FLOOR FINISH: carpet, carpet tiles, 90/10 wool/nylon | Default = carpet, vinyl also acceptable. |
| FLVY-007 | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant | to tea bench |
| FLSK-009 | SKIRTING: vinyl, feather edged, 150H, prefinished | Default = fealtheredge vinyl; floor vinyl coved skirting for vinyl floor |
| FLSK-010 | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished | |
| WLWA-004 | WALL FINISH: paint, acrylic, washable | |
| WLWA-007 | WALL FINISH: splashback | Selection of material to comply with Part D Infection Prevention and Control AusHFG. |
| DWWH-005 | WINDOW | |

Page: 1 Print Date: 20/03/2017



Room Name

Staff Room, 18m2

Room Number SRM-18

Fittings, Furniture and Equipment (FF&E) Items

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---|-------|-----|--|
| FIJO-059 | BENCH TOP: 600D, joinery under, laminate finish | 1 | 1 | with inset sink/ drainer. Length to suit layout, refer RLS or project specific requirements. |
| FQCW-016 | BIN: waste, general, 20L | 3 | 1 | Under bench. Size, number and type depends on Waste Management policy. |
| DWWD-006 | BLIND: venetian | 3 | 1 | |
| HYGE-003 | BOILING/CHILLED WATER UNIT: Combination | 1 | 1 | Unit underbench, with bench mounted spout. Tapware: instant hot/cold water tap to bench/sink top. |
| FIHR-006 | BRACKET: for display screen, wall mounted | 1 | 1 | optional |
| FQBS-015 | CHAIR: dining | 3 | 8 | Minimum. |
| FIJO-106 | CUPBOARD: drawer unit, 4 equal | 1 | 2 | under bench |
| FIJO-135 | CUPBOARD: underbench, double door, adj shelves | 1 | 2 | Number to suit layout, refer RLS or project specific requirements. |
| FIJO-143 | CUPBOARD: wall mount, double door, adj shelves | 1 | 3 | over bench, adjustable shelf. Number to suit layout, refer RLS or project specific requirements. |
| FIJO-153 | CUPBOARD: wall mount, shelf unit, adj shelves for microwave | 1 | 1 | over bench |
| FIDI-025 | DISPENSER: paper/hand towel | 2 | 1 | |
| FIDI-030 | DISPENSER: soap | 2 | 1 | |
| ITBU-011 | DISPLAY SCREEN: MATV | 3 | 1 | |
| FQCA-031 | FRIDGE: domestic, 250L | 3 | 1 | |
| FQBS-039 | LOUNGE: 1 seat | 3 | 2 | |
| FIBM-013 | NOTICEBOARD: fixed, fabric covered | 1 | 1 | 900mm x 900mm; optional |
| FQCA-067 | OVEN: microwave, domestic | 3 | 1 | |
| FIHR-047 | RACK: magazine, wall mounted | 3 | 1 | optional |
| HYBA-069 | SINK: single, with drainer, 930mmL | 1 | 1 | hot water |
| FQTA-059 | TABLE: square, 1100W, dining height | 3 | 1 | |
| FQTA-075 | TABLE: square, 600W, low height | 3 | 1 | |
| HYTP-029 | TAPWARE: boiling/chilled water unit (comb) | 1 | 1 | |
| HYTP-040 | TAPWARE: mixer, sink, accessible | 1 | 1 | |
| FIBM-019 | WHITEBOARD: fixed, magnetic | 2 | 2 | |

Engineering Services

| AusHFG code | Description | Group | Qty | Comment |
|-------------|---|-------|-----|----------------------------|
| ITCL-001 | ANNUNCIATOR: nurse call | 1 | 1 | to be audible in this room |
| ELGP-208 | GPO: double, wall mounted | 1 | 2 | |
| ELGP-109 | GPO: single, wall mounted | 1 | 3 | fridge, BWU, microwave |
| ITIN-026 | OUTLET: data, double RJ45, wall mounted | 1 | 1 | |
| ITIN-016 | OUTLET: data, single RJ45, wall mounted | 1 | 1 | |



Page: 2 Print Date: 20/03/2017



Room Data Sheet



Room Name

Staff Room, 18m2

Room Number SRM-18

| AusHFG code | Description | Group | Qty | Comment |
|-------------|--------------------------------|-------|-----|---|
| ITIN-070 | OUTLET: MATV | 1 | 1 | Optional. May be replaced with data outlet, in accordance with ICT policy |
| ELBO-015 | SWITCH: light, single | 1 | 1 | To Room. |
| ITNE-052 | TELEPHONE: handset, wall mount | 1 | 1 | |

AHHA

austratesian health infrastructure ellicace

communicati disussionation to flucture delicace

communicati disussionation to flucture delicace

communication to flucture delicace

communication to flucture delicace