

Room Name	Store - Photocopy/ Stationery, 10m2		Room Number STPS-10
Revision	5		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	10.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1-2 intermittently		
Acoustics	Sound attenuation level - High; acoustic privacy required		
Remarks			
Description / Special Requirements	A secure room for the storage of office stationery and for use of a freestanding, multifunctional device (MFD) and other office equipment as required. To be located adjacent Staff Station/Ward Clerk in IPU areas.		
SERVICES			
General Requirements	BODY PROTECTED = No		CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = Yes		AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes		LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No
Nurse Call	NURSE CALL SYSTEM = No		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLGE-001	CEILING: plasterboard, bulkhead, paint	Between above bench joinery and ceiling.
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	Optional, Depends on location, Lockable,
DWPR-001	DOOR PROTECTION: kickplate, to 300 AFFL	Optional, if door required.
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	Consistent with adjoining space; IPU, vinyl; office areas, carpet. Depends on Infection Control and cleaning policies.
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	Consistent with adjoining space; IPU, vinyl; office areas, carpet. Depends on Infection Control and cleaning policies.
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-012	WALL FINISH: prefinished	Behind waste bins.

Fittings, Furniture and Equipment (FF&E) Items

Room Name | **Store - Photocopy/ Stationery, 10m2**
Room Number STPS-10

AusHFG code	Description	Group	Qty	Comment
FIJO-059	BENCH TOP: 600D, joinery under, laminate finish	1	1	Length to suit layout, refer RLS or project specific requirements.
FQCW-016	BIN: waste, general, 20L	3	1	Size, type and number depends on waste management policy.
FQCW-029	BIN: waste, recycling, paper, 240L	3	1	Size, type and number depends on waste management policy.
FQCW-038	BIN: waste, secure	3	1	Size, type and number depends on waste management policy.
FIJO-116	CUPBOARD: tall, double door, adj shelves	1	1	Stationery storage, lockable
FIJO-136	CUPBOARD: underbench, double door, adj shelves, lockable	1	1	Paper storage. Number to suit layout, refer RLS or project specific requirements.
FIJO-141	CUPBOARD: underbench, single door, adj shelves, lockable	1	1	Paper storage. Number to suit layout, refer RLS or project specific requirements.
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	3	Or cupboards, over bench. Number to suit layout, refer RLS or project specific requirements.
ITNE-021	MULTIFUNCTION DEVICE: floorstanding	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	2	
ELGP-109	GPO: single, wall mounted	1	1	
LIFX-008	LIGHT: task light, built in	1	2	Optional - Under O/H shelving.
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	Number of outlets per faceplate as per ICT policy. 1 x MFD, 1 x bench mounted printer, if required.
ELBO-015	SWITCH: light, single	1	2	1 x room, 1 x task light under o/h joinery (if required).