



Room Name	Store - Sterile Stock, 24m2	Room Number STSS-24			
Revision	4				
Issue Date	20.03.17				
BRIEFING					
Briefed Area	24.00 m ²				
Hours of Operation	24 Hours				
Occupancy	1 - 2 intermittently				
Acoustics					
Remarks					
Description / Special Requirements	A room with an aseptic environment for storage and holding of sterile stock for use in the Operating Suite or other treatment areas. This area may also accommodate drugs in lockable cupboards and safe as required.				
SERVICES					
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No			
Air	AIRCONDITIONING = No	AIRCONDITIONING: hepa filtered = Yes			
	AIRCONDITIONING: positive pressure = Yes	AIRCONDITIONING: negative pressure = No			
	EXHAUST: room exhaust = No	VENTILATION = No			
Lighting	LIGHTING: colour corrected = No	LIGHTING: dimmable = No			
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No			
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No			
	LIGHTING: fluorescent, general = Yes	LIGHTING: indirect = No			
Nurse Call	NURSE CALL SYSTEM = No				

Room Fabrics

AusHFG code	Description	Comment
CLGE-001	CEILING: plasterboard, bulkhead, paint	
CLFS-005	CEILING: plasterboard, flush set, suspended, paint, scrub resistant	
CLCN-007	CORNICE: plasterboard, flush coved between wall and ceiling, paint	
DWGL-005	DOOR: 910mm c/o, single leaf, observation panel, solid core/glass, paint	Lockable, number to suit layout.
DWPR-006	DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished	Equal to Acrovyn
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	Equal to Acrovyn
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-005	WALL FINISH: paint, scrub resistant	
WLPR-019	WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC	Equal to Acrovyn

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-020	BENCH: 600D, open under, laminate finish	1	1	optional
FQBS-019	CHAIR: office, ergonomic, high	3	1	to bench, if provided
FQGE-005	CLOCK: analogue, battery operated	3	1	

AHHA

autralisian health infrastructura villence

oromouter in automotive for all or an extensive total con-

Page: 1 Print Date: 22/03/2017





Room Name

Store - Sterile Stock, 24m2

Room Number STSS-24

AusHFG code	Description	Group	Qty	Comment
FIJO-119	CUPBOARD: tall, double door, pharmacy shelves, lockable	1	1	with drug safe, optional
FIJO-143	CUPBOARD: wall mount, double door, adj shelves	1	1	over bench, optional
FIJO-157	CUPBOARD: wall mount, single door, adj shelves, lockable	1	1	
MMGE-088	SAFE: dangerous drugs, small	1	1	optional
FQSM-015	SHELVING: stainless steel wire mesh, mobile	3	11	
ITNE-049	TELEPHONE: handset, desktop	3	1	to writing bench, optional
MMGE-123	TROLLEY: instrument	3	2	
FIBM-018	WHITEBOARD: fixed	2	1	optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	1	
LIFX-008	LIGHT: task light, built in	1	1	under O/H cupboard
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	
ELBO-015	SWITCH: light, single	1	2	



Page: 2 Print Date: 22/03/2017