## Australasian Health Facility Guidelines

Room Data Sheet





## **Ultrasound Room**

Room Code	ULTR
Briefed Area	16.00 m²
Ceiling Height	2.7 m
Occupancy	1 patient; 1 visitor/carer; 1-2 staff
Hours of Operation	Up to 24 hours

Description

The Ultrasound Room provides the space and amenities for sonographers to perform diagnostic ultrasound imaging on patients.

Electrical	PROTECTION: body protected	<b>4</b>	HVAC	AIRCONDITIONING: general
	PROTECTION: cardiac protected			AIRCONDITIONING: HEPA filtered
Lighting	LIGHTING: general	$\checkmark$		AIRCONDITIONING: positive pressure
	LIGHTING: colour corrected	4		AIRCONDITIONING: negative pressure
	LIGHTING: dimmable	4		VENTILATION: exhaust
	LIGHTING: indirect	<b>4</b>		VENTILATION: supply
Nurse Call and	NURSE CALL SYSTEM: buttons / handset	1		VENTILATION: natural
Duress	NURSE CALL SYSTEM: annunciator		Medical Gas	MEDICAL GAS: general anaesthesia
	DURESS: fixed	4		MEDICAL GAS: special care
	DURESS: wireless coverage	<u>4</u>		MEDICAL GAS: special care, neonatal ventilation
		<b>V</b>		MEDICAL GAS: birthing
Security	ACCESS CONTROL: to door		Hydraulic	WATER: drinking
	ACCESS CONTROL: to item / joinery		-	WATER: specialty
	INTERCOM: service communications	4		DRAINAGE: sanitary
	INTERCOM: security and access control			DRAINAGE: specialty
	CCTV: camera coverage within room INTRUSION DETECTION: door monitoring		Fire	DETECTION: smoke
	INTRUSION DETECTION: door monitoring		riie	DETECTION 1
	INTROSION DETECTION. Spatial monitoring			DETECTION: heat
ICT and Audio Visual	AUDIO VISUAL: patient entertainment system		Shielding	SHIELDING: ionising radiation
Visuai	AUDIO VISUAL: visitor experiance system			SHIELDING: magentic and radio frequency
	AUDIO VISUAL: virtual collaboration system		Acoustics	SPEECH PRIVACY:
	AUDIO VISUAL: clinical support system			not private ······ moderate ······ private ····· confidential
	AUDIO VISUAL: digital operating room system			NOISE SENSITIVITY:
Accessibility	AUDIO: hearing augmentation			not sensitivemedium sensitivesensitive
	VISUAL: luminance contrast	<b>4</b>		NOISE GENERATION:
	SIGNAGE: accessible, statuatory			lowvery high
				iow inoderate high very high

## Additional Considerations

- The room will require sufficient clearance for the ultrasound machine and sonographer to be positioned to either side of the examination trolley and may need to occasionally accommodate a patient on a bed to either be transferred to the examination trolley or have the ultrasound performed while they are in the bed.
- Close access to a patient toilet and change room is required, with direct access from the room being preferred to support patients that have changed into gowns and require ultrasounds to be performed with a full bladder and then with an empty bladder.
- A combination of dimmable general room lighting and dimmable indirect lighting (wall and/ or ceiling fixtures) is preferred to obtain appropriate lighting levels and avoid glare on the screen of the ultrasound machine.
- Provision of height adjustable workstations or fixed joinery is to be in line with service requirements and local WHS policies.
- Hours of operation depend on the service in which this room is located. Ambulatory medical imaging services may only operate during business hours or extended business hours, some small hospital services may have an on-call, after-hours service. Large units are likely to provide a 24-hour service, especially where a satellite service is provided with an emergency department.
- Requirement for fixed and/or mobile duress to be confirmed to suit service requirements.

Issue date: 15.05.2025 Page: 1 of 4
Revision: 6 Copyright © 2025 Australasian Health Infrastructure Alliance (AHIA) Room code: ULTR

- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements.
- Provision of an intercom for staff communication within the department is dependent on service requirements. This function may be provided as part of the telephone system.
- The final services and configuration of the Medical Services Panel (MSP) medical gases, nurse call, power and data will be dependent on service requirements.
- The need for and extent of emergency power must be reviewed to suit site specific requirements and confirmed based on risk assessment considering the impact of a power outage on patient care/safety.



#### **Doors and Windows**

CODE		DESCRIPTION	COMMENT
	DOHI-104.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid	
	AFDPR-006.01	DOOR PROTECTION: plate, to 900H	to both sides of door



#### **Finishes**

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	minimum slip rating R10 / pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	
WLFI-002	WALL FINISH: paint, clinical areas	
WLFI-101	SPLASHBACK: vinyl	
WLPR-002	WALL PROTECTION: bedhead wall panel, low height	
CLFS-011	CEILING: flush set, suspended	ceiling tiles are also acceptable
CLFI-002	CEILING FINISH: paint, clinical areas	
CLCN-031	CORNICE: square set	or wall trim fixing for ceiling tiles



#### **Joinery**

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOCU-001	CUPBOARD: tall, single door	1	1	type and extent of storage to suit service requirements, operational policies for stock centralisation/decanting and infection prevention and control policies
JOGE-001	BULKHEAD: joinery	0	1	



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	2	1	
FIDI-231	DISPENSER: paper towel, wall mounted	2	1	to basin
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	2	1	
FIDI-256	DISPENSER: soap, wall mounted	2	1	to basin
FIDI-261	DISPENSER: soap, antiseptic, wall mounted	2	1	to basin

Issue date: 15.05.2025

Revision: 6

Page: 2 of 4 Room code: ULTR

ODE	DESCRIPTION	GROUP	QTY	COMMENT
FIHR-026	HOOK: coat	0	2	optional - for patient property, 1 mounted at 1200H if provided
FIHR-101	BRACKET: suction bottle, wall mounted	2	1	
FIHR-333	BRACKET: television/AV system display screen, single, fixed, ceiling mounted	2	1	to slave display screen
FIHR-481	BRACKET: sling, arm support, ceiling mounted	2	1	optional
FIRT-051	TRACK: curtain, privacy	1	1	to entry door
FQBS-101	CHAIR: visitor, clinical areas	3	1	
FQBS-171	CHAIR: office, ergonomic	3	1	
FQBS-202	STOOL: clinical areas, mobile	3	1	
FQCL-211	LINEN CARRIER: dirty, single skip	3	1	
FQDW-164.02	WORKSTATION: straight, adjustable height, electric, 720H nom, 750D x 1200W	3	1	
FQGE-101	CURTAIN: privacy screen	3	1	to entry door
FQGE-121	CLOCK: analogue, battery operated	3	1	
FQGE-161	STOOL: step	3	1	optional - for patient access to examination trolley, provision dependent on adjustable height range of trolley
FQWS-053	BIN: general waste, 50L	3	1	
FQWS-231	BIN: clinical waste, 20L	3	1	type, size and quantity of bins to be determined based on service requirements and waste management policies
HYBA-121	BASIN: type B, handwashing	1	1	
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	1	1	
ITCL-362	DISPLAY SCREEN: medical equipment, slave	0	1	for viewing ultrasound imaging by patient, may also be wall mounted
ITNE-071	TELEPHONE: handset, desktop	3	1	
ITNE-102	COMPUTER: dual display screens, central processing unit (CPU), keyboard and mouse, desktop	3	1	
MIUS-011	RACK: ultrasound probes, wall mounted	2	1	
MIUS-021	DEVICE: warmer, ultrasound gel, benchtop	3	1	may be integral to ultrasound machine
MMBE-156	TROLLEY: patient, examination	3	1	selection to suit service requirements, may require cut out section for cardiac scans
MMGE-056	POLE: patient positioning support handle, bed mounted	3	1	optional
MMGE-191	CANNISTER: suction bottle	3	1	
MMTR-001.02	TROLLEY: stainless steel, 490W x 490D x 900H nom, 2 tier	3	1	



# Major Medical Equipment (MME)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
MIUS-001	IMAGING DEVICE: ultrasound	2	1	



# **Engineering Services**

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-105	GPO: single, wall mounted, cleaner	0	1	

Issue date: 15.05.2025

Revision: 6

Page: 3 of 4 Room code: ULTR

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-106	GPO: single, ceiling mounted	0	1	to slave display screen
ELGP-201	GPO: double, wall mounted	1	1	to workstation, over desk for portable devices
ELGP-231	GPO: double, emergency power, wall mounted	0	1	low height, for examination trolley
ELGP-231	GPO: double, emergency power, wall mounted	0	2	to workstation
ELSW-022	SWITCH: light, dimmer, 2-gang	0	1	to general room lighting and indirect lighting
HYDR-201	DIRECT CONNECTION: waste water	0	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	0	1	to basin
HYTP-453	DIRECT CONNECTION: water, warm	0	1	to basin
ITCL-191	BUTTON: emergency, with cancel, wall mounted	0	1	
ITCL-251	HANDSET: patient to staff call	1	1	
ITIN-036	OUTLET: data, triple RJ45, wall mounted	1	1	to workstation
ITIN-061	OUTLET: data, HDMI, ceiling mounted	0	1	to slave display screen
ITSE-061	BUTTON: security, duress, fixed, wall mounted	1	1	
ITSE-166	INTERCOM: audio, slave, wall mounted	0	1	optional - inclusion dependent on service requirements and ICT policies



### **Medical Services Panels and Pendants**

CODE	DESCRIPTION	GROUP	QTY	COMMENT
Panel 1				
MMSP-051	MEDICAL SERVICES PANEL: wall mounted	0	1	
ELGP-146	GPO: single, emergency power, on service panel	0	8	
ELPR-073	RCD: residual current device, on services panel	0	2	
ITCL-133	BUTTON: patient to staff call, with cancel, with handset connection point, on services panel	1	1	
ITCL-183	BUTTON: staff assist, with cancel, on services panel	0	1	
ITIN-025	OUTLET: data, double RJ45, on services panel	0	2	
ITIN-065	OUTLET: data, HDMI, on services panel	0	2	for connecting ultrasound machine to slave display screen on ceiling, type of AV outlet to be confirmed to suit equipment requirements
MGAS-022	OUTLET: medical air, on services panel	0	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	0	1	
MGAS-062	OUTLET: suction, on services panel	0	1	
MGFP-021	FLOWMETER: medical air	3	1	
MGFP-041	FLOWMETER: oxygen	3	1	
MGFP-061	ADAPTER: suction	3	1	

Issue date: 15.05.2025

Revision: 6

Page: 4 of 4 Room code: ULTR