

Room Name	Waiting, Sub		Room Number	WAIT-S
Revision	6			
Issue Date	24.06.2022			
BRIEFING				
Briefed Area	5.00 m ²			
Hours of Operation	24 Hours			
Occupancy	Up to 5 patient/visitors			
Acoustics				
Remarks				
Description / Special Requirements	<p>The Waiting, Sub provides a satellite area for visitors, families and patients to wait within a unit, close to procedure/imaging rooms, consult rooms or offices. The size of satellite waiting areas can vary depending on service requirements; add 1.2m2 per additional person and allow 1.5m2 for additional wheelchair spaces as required.</p> <p>Additional Considerations:</p> <ul style="list-style-type: none"> • Wall protection is recommended to protect wall linings and finishes from damage due to movement of loose furniture. • An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements. • Hand hygiene facilities, such as alcohol-based hand rub, should be provided in line with local infection control policies. 			
SERVICES				
Electrical	BODY PROTECTED	<input type="checkbox"/>	CARDIAC PROTECTED	<input type="checkbox"/>
HVAC	AIRCONDITIONING	<input checked="" type="checkbox"/>	AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/>	VENTILATION	<input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input type="checkbox"/>	LIGHTING: dimmable	<input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/>	LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/>	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input checked="" type="checkbox"/>	LIGHTING: indirect	<input type="checkbox"/>
Security / Nurse Call	NURSE CALL SYSTEM	<input type="checkbox"/>		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	coordinated with adjacent area
CLCN-009	CORNICE: wall trim fixing	coordinated with adjacent area

Room Name | **Waiting, Sub**
Room Number WAIT-S

AusHFG code	Description	Comment
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	coordinated with adjacent area, carpet tiles are also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-022	WALL FINISH: vinyl, to 900 AFFL	as required to suit loose furniture layout; crash rails are also acceptable
WLPR-006	WALL PROTECTION: corner guards	coordinated with adjacent wall protection

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FQBS-027	CHAIR: visitor, bariatric	3	1	quantity dependent on service requirements
FQBS-032	CHAIR: waiting	3	2	
FIDI-001	DISPENSER: alcohol based hand rub	2	1	to suit local infection control policies
FIDI-056	HOLDER: document, A4	2	1	
FQTA-071	TABLE: square, 500W, low height	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	optional
ITCL-008	BUTTON: nurse call, staff assist	1	1	optional
ELGP-208	GPO: double, wall mounted	1	1	