

Room Name	Toilet - Patient	Room Number WCPT					
Revision	4						
Issue Date	18.01.2021						
BRIEFING							
Briefed Area	4.00 m <sup>2</sup>						
Hours of Operation	24 Hours						
Occupancy	1 patient; 1 staff assisting as required						
Acoustics	Sound attenuation level high, Acoustic privacy is required.						
Remarks	Source and readers research privacy to required.						
Description / Special Requirements	The Toilet - Patient provides a toilet and basin for use by patients (with or without assistance). Emergency release door hardware should be installed to allow staff access in an emergency. The entrance to the room should be flush with the adjoining floor for access in commode chairs/wheelchairs. Signage with braille tactile nominating 'Unisex Patient WC' required						
	nominating 'Unisex Patient WC' required						
SERVICES	nominating 'Unisex Patient WC' required						
SERVICES General Requirements	BODY PROTECTED	<b>√</b>	CARDIAC PROTECTED				
		<b>✓</b>	CARDIAC PROTECTED  AIRCONDITIONING: hepa filtered				
General Requirements	BODY PROTECTED						
General Requirements	BODY PROTECTED  AIRCONDITIONING		AIRCONDITIONING: hepa filtered				
General Requirements	BODY PROTECTED  AIRCONDITIONING  AIRCONDITIONING: positive pressure		AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure	v			
General Requirements  Air	BODY PROTECTED  AIRCONDITIONING  AIRCONDITIONING: positive pressure  EXHAUST: room exhaust	<ul><li>✓</li></ul>	AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION	V			
General Requirements  Air	BODY PROTECTED  AIRCONDITIONING AIRCONDITIONING: positive pressure EXHAUST: room exhaust  LIGHTING: colour corrected	<ul><li>✓</li></ul>	AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION  LIGHTING: dimmable LIGHTING: downlights, dimmable LIGHTING: fluorescent/LED, flush with ceiling, tamper	V			
General Requirements  Air	BODY PROTECTED  AIRCONDITIONING AIRCONDITIONING: positive pressure EXHAUST: room exhaust  LIGHTING: colour corrected LIGHTING: downlights	<ul><li>✓</li></ul>	AIRCONDITIONING: hepa filtered AIRCONDITIONING: negative pressure VENTILATION  LIGHTING: dimmable LIGHTING: downlights, dimmable	V			

## Room Fabrics

AusHFG code	Description	Comment
CLTI-014	CEILING: plasterboard, water resistant, drop-in tiles, prefinished, 600 x 1200	
CLCN-009	CORNICE: wall trim fixing	
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	with privacy latch, emergency release required if inward opening door
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	tiles are also acceptable
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	to be tiles if tiled floor
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	

## Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-011	BASIN: handwash, Type C	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FQCW-037	BIN: waste, sanitary	3	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	

AHHA
autriside hobb infrastruktur silkene
ermen is austrelan is det einer einer delter beiden

Page: 1 Print Date: 23/12/2020





Room Name

**Toilet - Patient** 

## **Room Number WCPT**

AusHFG code	Description	Group	Qty	Comment
FIDI-030	DISPENSER: soap	2	1	
FIDI-036	DISPENSER: toilet paper	1	1	
FIRT-006	GRAB RAIL: WC	1	1	
FIRT-008	GRAB RAIL: WC, hinged	1	1	optional
FIHR-026	HOOK: coat	1	2	
FIBM-006	MIRROR: fixed, glass	1	1	
HYTP-035	TAPWARE: mixer, basin, accessible	1	1	
HYWC-006	TOILET SUITE: patient	1	1	

## **Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	+ indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	+ indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	1	+ indicator button & light
HYDR-004	DRAIN: floor waste	1	1	
ELBO-015	SWITCH: light, single	1	1	

