

Room Name	X-Ray Viewing and Reporting		Room Number XRRR
Revision	4		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	12.00 m ²		
Hours of Operation	Available 24 Hours		
Occupancy	Up to 4		
Acoustics	Sound attenuation level medium, Acoustic privacy is required.		
Remarks			
Description / Special Requirements	Room within a Clinical or Diagnostic Unit for reviewing and reporting of patient imaging film or computerised images and to write reports.		
SERVICES			
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = Yes LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = No		

Room Fabrics

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWGL-002	DOOR: 910mm c/o, single leaf, half glazed, solid core/glass, paint	glazing optional
DWPR-003	DOOR PROTECTION: kickplate, to 300 AFFL, vinyl, prefinished	
FLCP-003	FLOOR FINISH: carpet, broadloom, 48 oz., 90/10 wool/nylon	vinyl also acceptable
DWOB-010	OBSERVATION: through door/s, glass, clear	
FLSK-009	SKIRTING: vinyl, feather edged, 150H, prefinished	or floor vinyl coved skirting
WLWA-004	WALL FINISH: paint, acrylic, washable	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
FIJO-020	BENCH: 600D, open under, laminate finish	1	2	to 2 sides of room
FQCW-016	BIN: waste, general, 20L	3	2	
FQBS-018	CHAIR: office, ergonomic	3	4	
FQGE-005	CLOCK: analogue, battery operated	3	1	
ITNE-009	COMPUTER: hi performance, for clinical / PACS use	3	2	for computerised images

Room Name | **X-Ray Viewing and Reporting**
Room Number XRRR

AusHFG code	Description	Group	Qty	Comment
FIJO-176	JOINERY UNIT: pidgeon holes for X-Ray films	1	4	above bench, vertical slots for X-Rays
FIBM-013	NOTICEBOARD: fixed, fabric covered	1	2	above bench
WLPT-003	PARTITION: laminate	1	2	under bench
FQSM-009	PEDESTAL: mobile, filing unit, 660H	3	2	under bench
ITNE-023	PRINTER: networked	3	1	
ITNE-049	TELEPHONE: handset, desktop	3	4	
MMGE-151	VIEWER: X-ray, (2) multiscreen	1	10	optional
FIBM-018	WHITEBOARD: fixed	2	1	900x900, optional

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	9	2 per workstation + 1- printer
ELGP-106	GPO: single, special, for equipment	1	2	X-ray viewers (optional)
LIFX-008	LIGHT: task light, built in	1	2	under O/H shleving
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	4	1 outlet per workstation for telephone
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	printer
ELBO-015	SWITCH: light, single	1	3	