

PATIENT AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 3/4	Qty x m2 Level 5/6	Remarks
1BR-ST	1 Bed Room, 15m2	Yes	15	15	Note 1. May be used as a Type S isolation room
1BR-IS-N	1 Bed Room - Isolation - Negative Pressure, 15m2	Yes	15	15	Provided as either a Class N or P, N Class rooms require an Anteroom
ANRM	Anteroom	Yes	6	6	Provided as part of N Class rooms.
	1 Bed Room, 16.5m2			16.5	Optional, may not be used by some jurisdictions
ENS-ST	Ensuite - Standard, 5m2	Yes	5	5	One per 1 Bed Room - Standard and 2 Bed Room
ENS-ACC	Ensuite - Accessible, 6m2	Yes	7	7	Note 2.
	1 Bed Room - Bariatric, 18m2		18	18	Number depends on patient profile
ENS-BA	Ensuite - Bariatric, 7m2	Yes	7	7	One per 1 Bed Room - Bariatric
2BR-ST	2 Bed Room, 20m2	Yes	25	25	
4BR-ST	4 Bed Room, 42m2	Yes	42	42	Projects panning to later reduce the number of 4 Bed Rooms, may plan to size these rooms at 50m2 and provide 2 ensuites
SHPT	Shower - Patient, 4m2	Yes	4	4	May be provided in 4 Bed Rooms
WCPT	Toilet - Patient, 4m2	Yes	4	4	May be provided in 4 Bed Rooms
	Discounted Circulation		32%	32%	Circulation rates may be higher with a high no of single bed rooms

SUPPORT AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 3/4	Qty x m2 Level 5/6	Remarks
BBEV-OP	Bay - Beverage, Open Plan 4m2	Yes	1 x 4	1 x 4	Open bay. If closed, increase to 5m2
BMT-4	Bay - Meal Trolley	Yes	1 x 4	1 x 4	Space dependent on size and capacity of meal trolleys
BFLW-OP	Bay - Flowers (Open)	Yes	1 x 2	1 x 2	Optional, dependent on local infection control policies
BHWS-B	Bay - Handwashing, Type B	Yes	1	1	Located in corridors
BHWS-PPE	Bay - Handwash/PPE	Yes	1.5	1.5	Shared between pairs of single rooms, nominated as isolation rooms
BLIN	Bay - Linen	Yes	2	2	At least 1 bay per 15 beds
BMEQ-4	Bay - Mobile Equipment, 4m2	Yes	4	4	Number depends on equipment to be stored and frequency of use. Ready access to bed rooms
BRES	Bay - Resuscitation	Yes	1 x 1.5	1 x 1.5	
CLRM-5	Cleaners Room, 5m2	Yes	1 x 5	1 x 5	Includes storage for dry goods
CLUR-14	Clean Utility, 14m2	Yes	1 x 14	1 x 14	Includes medications
	Medication Room	Yes	10	10	Separate room if medications not stored in Clean Utility. The size of Clean Utility Room would reduce if this approach is used.
DTUR-12	Dirty Utility, 12m2	Yes	12	12	More than one room may be required to minimize travel distances
DISP-10	Disposal Room, 10m2	Yes	10	10	May be shared between two Units
INTF	Interview Room	Yes	9	9	
OFF-CLW	Office - Clinical Workroom	Yes	15	15	Locate near staff station
SSTN-14	Staff Station, 14m2	Yes	14	14	
SSTN-10	Staff Station, 5m2	Yes	5	5	Optional decentralized staff based. Location and no dependent on unit configuration.
STPS-8	Store - Photocopy/Stationary, 8m2	Yes	8	8	Collocate with Staff Station
STEQ-20	Store - Equipment, 20m2	Yes	20	20	Size dependent on equipment stored, frequency of use and number of bays
STGN-9	Store - General, 9m2	Yes	9	9	
TRMT	Treatment Room	Yes	14	14	May be required in specialist units, or shared between two units. Depends on operational policy. Also to be used for allied health treatments that cannot be undertaken in the bed room space
	Discounted Circulation		32%	32%	Circulation rates may be higher with a high no of single bed rooms

STAFF AREAS - OFFICES AND AMENITIES

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 3/4	Qty x m2 Level 5/6	Remarks
OFF-S9	Office - Single Person, 9m2	Yes	1 x 9	1 x 9	Unit Manager
OFF-3P	Office - Three Person Shared, 15m2	Yes	1 x 15	15	May be used to accommodate allied health and/or medical staff depending on operational policy
OFF-2P	Office - Two Person Shared, 12m2	Yes	1 x 12	12	May be used to accommodate CNC and CNE, depending on service demand and operational policy
SRM-15	Staff Room, 15m2	Yes	1 x 15	1 x 15	Includes a beverage bay
PROP-2	Property Bay - Staff	Yes	1 x 3	1 x 3	Capacity for all staff and students located on the IPU
WCST	Toilet - Staff, 3m2	Yes	3	3	Number depends on staffing
	Discounted Circulation		32%	32%	Circulation rates may be higher with a high no of single bed rooms

SHARED AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 3/4	Qty x m2 Level 5/6	Remarks
BATH	Bathroom	Yes	1 x 15	1 x 15	Usually provided at one bath per floor or shared between two units
MEET-L-20	Meeting Room	Yes	-	1 x 18	Tutorial. Size dependent on room usage requirements
LNPF-20	Lounge - Patient / Family, 20m2	Yes	1 x 20	1 x 20	Optional, dependent on overarching models used for the health service.
WCPU-3	Toilet - Public, 3m2	Yes	1 x 3	1 x 3	
WCAC	Toilet - Accessible, 6m2	Yes	6	6	
STGN-9	Store - General	Yes		12	Optional; may be provided between two IPUs to store essential allied health equipment including mobility aids. Located near IPUs dependent on overarching equipment models for the health service.
	Discounted Circulation		32%	32%	Circulation rates may be higher with a high no of single bed rooms